

2554

Sponsor(s): Representatives Wood, Clements, Simpson, Benson, Cooper, Morell, Lovick, Dunshee and Santos

Brief Description: Requiring fire detection devices for the hearing impaired in larger apartment buildings.

**HB 2554 - DIGEST**

Directs the building code council to adopt rules by December 1, 2002, requiring that all new apartment buildings with fifty or more units that are classified as group R, division 1 apartment buildings as defined in the state building code, and are built or manufactured in this state after July 31, 2003, be installed with a minimum of one smoke detection device for hearing impaired persons for each fifty units.