

2886

Sponsor(s): Representatives Simpson, Wood, Cooper, Lovick, Dunshee, Santos, Conway, Chase, Lysen and Kenney

Brief Description: Requiring installation of fire alarms for hearing impaired persons.

**HB 2886 - DIGEST**

(SEE ALSO PROPOSED 1ST SUB)

Requires that, if the dwelling unit is occupied by a hearing impaired person, at least one smoke detection device for hearing impaired persons shall be installed on each level of the dwelling unit and in each bedroom of the dwelling unit occupied by a hearing impaired person.