

SENATE BILL REPORT

HB 1542

As of March 13, 2023

Title: An act relating to requiring automated external defibrillators to be available and accessible when work is being performed on high voltage lines and equipment.

Brief Description: Requiring automated external defibrillators to be available and accessible when work is being performed on high voltage lines and equipment.

Sponsors: Representatives Bronoske, Fosse, Berry, Hackney, Abbarno, Griffey, Walsh, Ortiz-Self, Taylor, Ramel, Simmons, Jacobsen, Schmidt, Graham, Ormsby, Pollet, Kloba, Doglio, Bateman, Macri, Leavitt and Timmons.

Brief History: Passed House: 3/4/23, 95-0.

Committee Activity: Labor & Commerce: 3/14/23.

Brief Summary of Bill

- Requires an automated external defibrillator be available and accessible when work is being performed on high voltage lines and equipment, or when line-clearance tree trimming is conducted in close proximity to high voltage lines or equipment.

SENATE COMMITTEE ON LABOR & COMMERCE

Staff: Jarrett Sacks (786-7448)

Background: Under the Washington Industrial Health and Safety Act, the Department of Labor and Industries (L&I) adopts rules and regulations of safety and health standards governing the conditions of employment in all work places. L&I sets occupational health and safety standards that are at least as effective as the federal standards.

Current rules and regulations provide safety standards for the operation, maintenance, and construction of electric power generation, control, transformation, transmission, and

This analysis was prepared by non-partisan legislative staff for the use of legislative members in their deliberations. This analysis is not part of the legislation nor does it constitute a statement of legislative intent.

distribution of electrical lines and equipment, as well as line-clearance tree-trimming. Among other requirements, persons trained in first aid and cardiopulmonary resuscitation must be available when employees are performing work on or associated with exposed lines or equipment energized at 50 volts or more.

An automated external defibrillator (AED) is a medical device used in the event of a sudden cardiac arrest that analyzes the heart rhythm and delivers an electrical shock to re-establish an effective heart rhythm.

Summary of Bill: Employers with employees who operate, maintain, or construct high voltage lines and equipment or who conduct line-clearance tree trimming in close proximity to high voltage lines and equipment must:

- make an AED available and accessible to employees when work is being performed on, or in close proximity to, high voltage lines and equipment by two or more employees;
- conduct regular maintenance and annual inspections on the AED; and
- provide training or facilitate training to ensure there are at least two employees proficient on the proper and safe use of the AED.

To be considered proficient, an employee must have completed initial or updated training within the previous two years.

High voltage lines or equipment means any energized communication line, electric supply line, or equipment with a voltage of 601 or greater.

Appropriation: None.

Fiscal Note: Available.

Creates Committee/Commission/Task Force that includes Legislative members: No.

Effective Date: The bill takes effect on January 1, 2024.