

**(Effective until October 29, 2023)**

**WAC 51-52-0515 Section 515—Waste or linen chute venting.**

**515.1 General.** Waste or linen chutes shall be gravity vented per NFPA 82.

EXCEPTION: Waste or linen chutes may be mechanically ventilated by an exhaust fan. The exhaust fan in accordance with *International Building Code* Section 713.13.7.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-03-041, § 51-52-0515, filed 1/8/20, effective 7/1/20; WSR 16-01-148, § 51-52-0515, filed 12/21/15, effective 7/1/16.]

**(Effective October 29, 2023)**

**WAC 51-52-0515 Section 515—Waste or linen chute venting.**

**515.1 General.** Waste or linen chutes shall be gravity vented in accordance with NFPA 82.

EXCEPTION: Waste or linen chutes may be mechanically ventilated by an exhaust fan in accordance with Section 713.13.7 of the *International Building Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-02-055 and 23-12-106, § 51-52-0515, filed 1/3/23 and 6/7/23, effective 10/29/23; WSR 20-03-041, § 51-52-0515, filed 1/8/20, effective 7/1/20; WSR 16-01-148, § 51-52-0515, filed 12/21/15, effective 7/1/16.]