

(Effective until October 29, 2023)

WAC 51-52-1101 Section 1101—Refrigeration, general.

1101.2 Factory-built equipment and appliances. *Listed and labeled self-contained, factory-built equipment and appliances shall be tested in accordance with UL 207, 412, 471, 1995, or 60335-2-40. Such equipment and appliances are deemed to meet the design, manufacture and factory test requirements of this code if installed in accordance with their listing and the manufacturer's instructions.*

1101.6 General. Refrigeration systems shall comply with the requirements of this code and, except as modified by this code, ASHRAE 15. Ammonia-refrigerating systems shall comply with this code and, except as modified by this code, ASHRAE 15, IIAR 2, IIAR 3, IIAR 4, and IIAR 25.

EXCEPTION: Systems utilizing A2L refrigerants complying with ASHRAE 15 are deemed to meet this code.

[Statutory Authority: RCW 19.27.031, 19.27.074, and chapter 19.27 RCW. WSR 22-09-009, § 51-52-1101, filed 4/8/22, effective 5/9/22.]

(Effective October 29, 2023)

WAC 51-52-1101 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-02-055 and 23-12-106, § 51-52-1101, filed 1/3/23 and 6/7/23, effective 10/29/23. Statutory Authority: RCW 19.27.031, 19.27.074, and chapter 19.27 RCW. WSR 22-09-009, § 51-52-1101, filed 4/8/22, effective 5/9/22.]