

(Effective October 29, 2023)

WAC 51-52-21409 Section 409 (IFGC)—Drips and sloped piping.

Table 409.1.1  
Natural Gas Valve Standards

Valve Standards	Appliance Shutoff Valve Application Up to 1/2 psig Pressure	Other Valve Applications			
		Up to 1/2 psig Pressure	Up to 2 psig Pressure	Up to 5 psig Pressure	Up to 125 psig Pressure
ANSI Z21.15/CGA 9.1	X	--	--	--	--
ASME B16.44	X	X	X <sup>a</sup>	X <sup>b</sup>	--
ASME B16.33	X	X	X	X	X
ASME B16.38	--	X	X	X	X

For SI: 1 pound per square inch gauge = 6.895 cPsa

a. If labeled 2G.

b. If labeled 5G.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-02-055 and 23-12-106, § 51-52-21409, filed 1/3/23 and 6/7/23, effective 10/29/23.]