

Chapter 51-54A WAC
STATE BUILDING CODE ADOPTION AND AMENDMENT OF THE 2021 EDITION OF THE
INTERNATIONAL FIRE CODE

Last Update: 11/15/23

WAC

51-54A-001	Authority.
51-54A-002	Purpose.
51-54A-003	International Fire Code.
51-54A-007	Exceptions.
51-54A-008	Implementation.
51-54A-0101	Section 101.
51-54A-0105	Permits.
51-54A-0202	General definitions.
51-54A-0301	Permits.
51-54A-0302	Definitions.
51-54A-0307	Open burning, recreational fires and portable outdoor fireplaces.
51-54A-0308	Open flames.
51-54A-0314	Indoor displays.
51-54A-0315	Reserved.
51-54A-0319	Mobile food preparation vehicles.
51-54A-0321	Artificial combustible vegetation.
51-54A-0322	Lithium batteries.
51-54A-0323	Powered micromobility devices and powered industrial trucks.
51-54A-0401	General.
51-54A-0402	Definitions.
51-54A-0403	Emergency preparedness requirements.
51-54A-0404	Fire safety and evacuation plans.
51-54A-0405	Reserved.
51-54A-0406	Employee training and response procedures.
51-54A-0408	Reserved.
51-54A-0501	Reserved.
51-54A-0503	Fire apparatus access roads.
51-54A-0507	Fire protection water supplies.
51-54A-0508	Fire command center.
51-54A-0510	Emergency responder communication coverage.
51-54A-0605	Fuel fired appliances.
51-54A-0606	Section 606—Commercial cooking equipment and systems.
51-54A-0607	Reserved.
51-54A-0609	Reserved.
51-54A-0701	Reserved.
51-54A-0806	Decorative vegetation in new and existing buildings.
51-54A-0901	General.
51-54A-0903	Automatic sprinkler systems.
51-54A-0904	Alternative automatic fire-extinguishing systems.
51-54A-0907	Fire alarm and detection systems.
51-54A-0908	Reserved.
51-54A-0909	Section 909—Smoke control systems.
51-54A-0913	Section 913—Fire pumps.
51-54A-0915	Carbon monoxide detection.
51-54A-0916	Reserved.
51-54A-0918	Reserved.
51-54A-1003	General means of egress.
51-54A-1004	Occupant load.
51-54A-1005	Means of egress sizing.
51-54A-1006	Number of exits and exit access doorways.
51-54A-1007	Reserved.
51-54A-1008	Means of egress illumination.
51-54A-1009	Accessible means of egress.
51-54A-1010	Doors, gates and turnstiles.
51-54A-1011	Stairways.
51-54A-1012	Ramps.
51-54A-1014	Section 1014—Handrails.
51-54A-1015	Section 1015—Guards.
51-54A-1017	Exit access travel distance.
51-54A-1018	Reserved.
51-54A-1019	Reserved.
51-54A-1020	Corridors.
51-54A-1021	Reserved.
51-54A-1023	Section 1023—Interior exit stairways and ramps.
51-54A-1028	Reserved.
51-54A-1030	Reserved.
51-54A-1103	Fire safety requirements for existing buildings.
51-54A-1104	Means of egress for existing buildings.
51-54A-1105	Construction requirements for existing Group I-2.
51-54A-1201	General.
51-54A-1204	Reserved.
51-54A-1205	Section 1205—Solar photovoltaic power systems.
51-54A-1206	Stationary fuel cell power systems.
51-54A-1207	Electrical energy storage systems.
51-54A-2404	Spray finishing.
51-54A-3103	Temporary tents and membrane structures.
51-54A-3303	Administrative safety controls.

51-54A-3304 Protection of combustible materials.
 51-54A-3305 Ignition source controls.
 51-54A-3306 Fire protection systems and devices.
 51-54A-3307 Fire department site access and water supply.
 51-54A-3308 Motorized construction equipment.
 51-54A-3309 Hazardous materials.
 51-54A-3310 Additional safeguards for occupied buildings.
 51-54A-3311 Additional safeguards for Type I and II construction.
 51-54A-3312 Additional safeguards for Type IV-A, IV-B, and IV-C construction.
 51-54A-3313 Water supply for fire protection.
 51-54A-3314 Standpipes.
 51-54A-3315 Automatic sprinkler system.
 51-54A-3316 Portable fire extinguishers.
 51-54A-3317 Motorized construction equipment.
 51-54A-3318 Safeguarding roofing operations.
 51-54A-3601 Marinas—Scope.
 51-54A-3602 Definitions.
 51-54A-3604 Fire protection equipment.
 51-54A-3800 Reserved.
 51-54A-3900 Reserved.
 51-54A-3904 Reserved.
 51-54A-4000 Reserved.
 51-54A-4900 Fixed guideway transit and passenger rail systems.
 51-54A-5003 Reserved.
 51-54A-5306 Medical gas systems.
 51-54A-5307 Reserved.
 51-54A-5601 General.
 51-54A-5704 Storage.
 51-54A-5706 Special operations.
 51-54A-5707 Section 5707—On-demand mobile fueling operations.
 51-54A-6108 Fire protection.
 51-54A-8000 Referenced standards.
 51-54A-8100 Reserved.
 51-54A-8200 Reserved.

WAC 51-54A-001 Authority. These rules are adopted under the authority of chapter 19.27 RCW.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-001, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-002 Purpose. The purpose of these rules is to implement the provisions of chapter 19.27 RCW, which provides that the State Building Code Council shall maintain the State Building Code in a status which is consistent with the purpose as set forth in RCW 19.27.020. In maintaining the codes the council shall regularly review updated versions of the codes adopted under the act, and other pertinent information, and shall amend the codes as deemed appropriate by the council.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-002, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-003 International Fire Code. The 2021 edition of the International Fire Code, published by the International Code Council is hereby adopted by reference with the following additions, deletions, and exceptions.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-003, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-003, filed 11/27/19, effective 7/1/20; WSR 16-05-065, § 51-54A-003, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031,

19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-003, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-007 Exceptions. The exceptions and amendments to the International Fire Code contained in the provisions of chapter 19.27 RCW shall apply in case of conflict with any of the provisions of these rules.

Codes referenced which are not adopted through RCW 19.27.031 or chapter 19.27A RCW shall not apply unless specifically adopted by the authority having jurisdiction.

The provisions of this code do not apply to temporary growing structures used solely for the commercial production of horticultural plants including ornamental plants, flowers, vegetables, and fruits. "Temporary growing structure" means a structure that has the sides and roof covered with polyethylene, polyvinyl, or similar flexible synthetic material and is used to provide plants with either frost protection or increased heat retention. A temporary growing structure is not considered a building for purposes of this code.

The provisions of this code do not apply to the construction, alteration, or repair of temporary worker housing except as provided by rule adopted under chapter 70.114A RCW or chapter 37, Laws of 1998 (2SSB 6168). "Temporary worker housing" means a place, area, or piece of land where sleeping places or housing sites are provided by an employer for his or her employees or by another person, including a temporary worker housing operator, who is providing such accommodations for employees, for temporary, seasonal occupancy, and includes "labor camps" under RCW 70.54.110.

The manufacture, storage, handling, sale and use of fireworks shall be governed by chapter 70.77 RCW and by chapter 212-17 WAC and local ordinances consistent with chapter 212-17 WAC.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-007, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-007, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-007, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-05-065, § 51-54A-007, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-007, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-008 Implementation. The *International Fire Code* adopted by chapter 51-54A WAC shall become effective in all counties and cities of this state on March 15, 2024.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-008, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-008, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-11-066, § 51-54A-008, filed 5/14/21, effective 6/14/21; WSR 19-24-058, § 51-54A-008, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-008, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-008, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0101 Section 101.

Reserved.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0101, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0101, filed 12/18/19, effective 7/1/20; WSR 16-05-065, § 51-54A-0101, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0101, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0105 Permits.

105.5.14.1 Lithium batteries. An operational permit is required for an accumulation of more than 15 cubic feet (0.42 m) of lithium-ion and lithium metal batteries, where required by Section 322.1.

105.5.32 Mobile food preparation vehicles. A permit is required for mobile preparation vehicles equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems.

105.6.25 Underground supply piping for automatic sprinkler system. A construction permit is required for the installation of the portion of the underground water supply piping, public or private, supplying a water-based fire protection system. The permit shall apply to all underground piping and appurtenances downstream of the first control valve on the lateral piping or service line from the distribution main to 1 foot above finished floor of the facility with the fire protection system. Maintenance performed in accordance with this code is not considered to be a modification and does not require a permit.

EXCEPTIONS: 1. When the underground piping is installed by the aboveground piping contractor.
2. Underground piping that serves a fire protection system installed in accordance with NFPA 13D.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0105, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0105, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0105, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0105, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0105, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0105, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0105, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0202 General definitions.

SECTION 202 GENERAL DEFINITIONS

ADULT FAMILY HOME. A dwelling, licensed by the state of Washington department of social and health services, in which a person or persons provide personal care, special care, room and board to more than one but not more than six adults who are not related by blood or marriage to the person or persons providing the services. An existing adult family home may provide services to up to eight adults upon approval from the department of social and health services under RCW 70.128.066 and in accordance with Section 903.

ALERT SIGNAL. A distinctive signal indicating the need for trained personnel and occupants to initiate a specific action, such as shelter-in-place.

ALERT SYSTEM. Approved devices, equipment and systems or combinations of systems used to transmit or broadcast an alert signal.

ASSISTED LIVING FACILITY. A home or other institution, licensed by the state of Washington, providing housing, basic services and assuming general responsibility for the safety and well-being of residents under chapters 18.20 RCW and 388-78A WAC. These facilities may provide care to residents with symptoms consistent with dementia requiring additional security measures.

CHILD CARE. For the purposes of these regulations, child care is the care of children during any period of a 24-hour day.

CHILD CARE, FAMILY HOME. A child care facility, licensed by Washington state, located in the dwelling of the person or persons under whose direct care and supervision the child is placed, for the care of 12 or fewer children, including children who reside at the home.

CLUSTER. Clusters are multiple *portable school classrooms* separated by less than the requirements of the building code for separate buildings.

COVERED BOAT MOORAGE. A pier or system of floating or fixed access ways to which vessels on water may be secured and any portion of which are covered by a roof.

CUSTODIAL CARE. Assistance with day-to-day living tasks; such as assistance with cooking, taking medication, bathing, using toilet facilities, and other tasks of daily living. Custodial care includes persons receiving care who have the ability to respond to emergency situations and may receive limited verbal or physical assistance. These care recipients may evacuate at a slower rate and/or who have mental and psychiatric complications.

ELECTRICAL CODE. The National Electrical Code, promulgated by the National Fire Protection Association, as adopted by rule or local ordinance under the authority of chapter 19.28 RCW.

EMERGENCY RESPONDER COMMUNICATIONS ENHANCEMENT SYSTEM (ERCES). An infrastructure solution installed within a building to enhance the communications capabilities for first responders that utilizes solutions such as a signal booster, voting receiver, base station, or other technology capable of enhancing the radio frequency (RF) to ensure effective public safety communications.

FREQUENCY. The particular waveband at which a communications system broadcasts or transmits.

FREQUENCY LICENSE HOLDER(S). The person(s) or entity(s) that are issued the license from the frequency licensing authority of United States or other country of jurisdiction for the frequencies being used by both the in-building emergency responder communications enhancement system and the emergency services communications system that it enhances.

FREQUENCY LICENSING AUTHORITY. The government authority in a country or territory that issues frequency licenses for the use of communications frequencies by authorized entities and individuals.

GRAVITY-OPERATED DROP OUT VENTS. Automatic smoke and heat vents containing heat-sensitive glazing designed to shrink and drop out of the vent openings when exposed to fire.

HOSPICE CARE CENTER. A building or portion thereof used on a 24-hour basis for the provision of hospice services to terminally ill inpatients.

LIMITED VERBAL OR PHYSICAL ASSISTANCE. Persons who, because of age, physical limitations, cognitive limitations, treatment or chemical dependency, and may not independently recognize, respond, or evacuate without limited verbal or physical assistance during an emergency situation. Verbal assistance includes prompting, giving, and repeating instructions. Physical assistance includes assistance with transfers to walking aids or mobility devices and assistance with egress.

MOBILE FOOD PREPARATION VEHICLE. Mobile food preparation vehicles that are equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems for the purpose of preparing and serving food to the public. Vehicles intended for private recreation shall not be considered mobile food preparation vehicles.

MOTOR VEHICLE. Includes, but not limited to, a vehicle, machine, tractor, trailer or semitrailer, or any combination thereof, propelled or drawn by mechanical power and designed for use upon the highways in the transportation of passengers or property. It does not include a vehicle, locomotive or car operated exclusively on a rail or rails, or a trolley bus operated by electric power derived from a fixed overhead wire, furnishing local passenger transportation similar to street-railway service. The term "motor vehicle" also includes freight containers or cargo tanks used, or intended for use, in connection with motor vehicles.

NIGHTCLUB. An A-2 Occupancy use in which the aggregate area of concentrated use of unfixed chairs and standing space that is specifically designated and primarily used for dancing or viewing performers exceeds 350 square feet (32.5 m²), excluding adjacent lobby areas. "Nightclub" does not include theaters with fixed seating, banquet halls, or lodge halls.

OCCUPANCY CLASSIFICATION. For the purposes of this code, certain occupancies are defined as follows:

Institutional Group I-1. Institutional Group I-1 occupancy shall include buildings, structures or portions thereof for more than 16 persons excluding staff, who reside on a 24-hour basis in a supervised environment and receive custodial care. Buildings of Group I-1 shall be classified as one of the occupancy conditions indicated below. This group shall include, but not be limited to, the following: Assisted living facilities licensed under chapter 388-78A WAC and residential treatment facilities licensed under chapter 246-337 WAC shall be classified as Group I-1, Condition 2.

No change to the rest of the occupancy conditions.

Group I-2. This occupancy shall include buildings and structures used for medical care on a 24-hour basis for more than five persons who are incapable of self-preservation. This group shall include, but not be limited to, the following:

- Foster care facilities
- Detoxification facilities

Hospice care centers
Hospitals
Nursing homes
Psychiatric hospitals

Five or fewer persons receiving care. A facility such as the above with five or fewer persons receiving such care shall be classified as Group R-3 or shall comply with the *International Residential Code* provided that an *automatic sprinkler system* is installed in accordance with Section 903.3.1.3 or with Section P2904 of the *International Residential Code*.

Family home child care. Family home child care licensed by Washington state for the care of 12 or fewer children shall be classified as Group R-3 or shall comply with the *International Residential Code*.

Adult care facility. A facility that provides accommodations for less than 24 hours for more than 5 unrelated adults and provides supervision and personal care services shall be classified as Group I-4.

EXCEPTION: Where the occupants are capable of responding to an emergency situation without physical assistance from the staff, the facility shall be classified as Group R-3.

Child care facility. Child care facilities that provide supervision and personal care on a less than 24-hour basis for more than 5 children 2 1/2 years of age or less shall be classified as Group I-4.

EXCEPTIONS: 1. A child day care facility that provides care for more than five but no more than 100 children 2 1/2 years or less of age, where the rooms in which the children are cared for are located on a level of exit discharge serving such rooms and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group E.

2. Family child care homes licensed by Washington state for the care of 12 or fewer children shall be classified as Group R-3.

Residential Group R. Residential Group R includes, among others, the use of a building or structure, or a portion thereof, for sleeping purposes when not classified as an Institutional Group I or when not regulated by the *International Residential Code*. This group shall include:

R-1 Residential occupancies containing sleeping units where the occupants are primarily transient in nature, including:

Boarding houses (transient) with more than 10 occupants

Congregate living facilities (transient) with more than 10 occupants

Hotels (transient)

Motels (transient)

R-2 Residential occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature, including:

Apartment houses

Congregate living facilities (nontransient) with more than 16 occupants

Boarding houses (nontransient) with more than 16 occupants

Convents

Dormitories

Fraternities and sororities

Monasteries

Hotels (nontransient)

Live/work units

Motels (nontransient)

Vacation timeshare properties

R-3 Residential occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-4, or I, including:

Buildings that do not contain more than two dwelling units.

Care facilities that provide accommodations for five or fewer persons receiving care.

Congregate living facilities (nontransient) with 16 or fewer occupants.

Boarding houses (nontransient) with 16 or fewer occupants

Convents

Dormitories

Fraternities and sororities

Monasteries

Congregate living facilities (transient) with 10 or fewer occupants.

Boarding houses (transient) with 10 or fewer occupants

Lodging houses (transient) with five or fewer guestrooms and 10 or fewer occupants

Care facilities within a dwelling. Care facilities for five or fewer persons receiving care that are within a single-family dwelling are permitted to comply with the *International Residential Code* provided an automatic sprinkler system is installed in accordance with Section 903.3.1.3 or with Section P2904 of the *International Residential Code*.

Adult family homes, family home child care. Adult family homes and family home child care facilities that are within a single-family home are permitted to comply with the *International Residential Code*.

Foster family care homes. Foster family care homes licensed by Washington state are permitted to comply with the *International Residential Code*, as an accessory use to a dwelling, for six or fewer children including those of the resident family.

PORTABLE SCHOOL CLASSROOM. A prefabricated structure consisting of one or more rooms with direct exterior egress from the classroom(s). The structure is transportable in one or more sections, and is designed to be used as an educational space with or without a permanent foundation. The structure shall be capable of being demounted and relocated to other locations as needs arise.

POWERED MICROMOBILITY DEVICES. Motorized bicycles, motorized scooters, and other personal mobility devices powered by a rechargeable battery. The term does not include motor vehicles that are required to be registered with the department of motor vehicles for the state or jurisdiction.

RECALL SIGNAL. An electrically or mechanically operated signal used to recall occupants after an emergency drill or to terminate a shelter-in-place event that shall be distinct from any alarm or alert signal used to initiate an emergency plan, or other signals.

SHELTER-IN-PLACE. An emergency response used to minimize exposure of facility occupants to chemical or environmental hazards by taking refuge in predetermined interior rooms or areas where actions are taken to isolate the interior environment from the exterior hazard.

SPECIAL HAZARDS SUPPRESSION SYSTEMS. Wet-chemical systems (NFPA 17A), Dry-chemical systems (NFPA 17), Foam systems (NFPA 11), Carbon dioxide systems (NFPA 12), Halon systems (NFPA 12A), Clean-agent systems (NFPA 2001), Automatic water mist systems (NFPA 750), Aerosol fire-extinguishing systems (NFPA 2010), and Explosion prevention systems (NFPA 69).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0202, filed 11/15/23, effective 3/16/24; WSR 22-13-093,

23-12-107, and 23-20-027, § 51-54A-0202, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0202, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0202, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0202, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.020, and 19.27.031. WSR 14-24-090, § 51-54A-0202, filed 12/1/14, effective 5/1/15. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0202, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0301 Permits.

301.2 Permits. Permits shall be required as set forth in Section 105.5 for the activities or uses regulated by Sections 306, 307, 308, 315, 320, and 322.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0301, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0302 Definitions.

302.1 Definitions. The following terms are defined in Chapter 2:

3D PRINTER;
ADDITIVE MANUFACTURING;
BONFIRE;
HI-BOY;
HIGH-VOLTAGE TRANSMISSION LINE;
MOBILE FOOD PREPARATION VEHICLE;
OPEN BURNING;
PORTABLE OUTDOOR FIREPLACE;
POWERED INDUSTRIAL TRUCK;
RECREATIONAL FIRE;
SKY LANTERN.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0302, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0307 Open burning, recreational fires and portable outdoor fireplaces.

307.2.1 Authorization. Where required by state or local law or regulations, open burning shall only be permitted with prior approval from the state or local air and water quality management authority, provided that all conditions specified in the authorization are followed. See also chapter 173-425 WAC.

307.4.2 Recreational fires. Recreational fires shall not be conducted within 25 feet of a structure or combustible material. Conditions which could cause a fire to spread within 25 feet of a structure shall be eliminated prior to ignition. See also chapter 173-425 WAC.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0307, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0308 Open flames.

308.1.7 Religious ceremonies. Participants in religious ceremonies shall not be precluded from carrying hand-held candles. See RCW 19.27.031(3).

308.1.7.1 Aisles and exits. Candles shall be prohibited in areas where occupants stand, or in an aisle or exit.

EXCEPTION: Candles used in religious ceremonies.

308.1.9 Decorative open flame tables. Gas-fired portable or fixed open flame fire tables and fireplaces are required to be provided with approved protection devices to prevent occupants from using flame, and from flame being exposed to combustible material. A fire extinguisher shall be located within 75 feet of travel distance or as approved. Where located indoors, the supply gas valve shall be interlocked with building fire alarm and/or fire sprinklers, where provided.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0308, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0308, filed 1/20/21, effective 2/20/21; WSR 16-03-055, § 51-54A-0308, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0308, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0314 Indoor displays.

314.4 Vehicles. Liquid- or gas-fueled vehicles, boats, aircraft or other motorcraft shall not be located indoors except as follows:

1. The engine starting system is made inoperable or ignition batteries are disconnected except where the fire code official requires that the batteries remain connected to maintain safety features.

2. Fuel in fuel tanks does not exceed any of the following:

2.1. Class I, II, and III liquid fuel does not exceed one-quarter tank or 5 gallons (19 L), whichever is less.

2.2. LP gas does not exceed one-quarter tank or 6.6 gallons (25 L), whichever is less.

2.3. CNG does not exceed one-quarter tank or 630 cubic feet (17.8 m³), whichever is less.

2.4. Hydrogen does not exceed one-quarter tank or 2,000 cubic feet (0.57 m³), whichever is less.

3. Fuel tanks and fill openings are closed and sealed to prevent tampering.

4. Vehicles, aircraft, boats or other motorcraft equipment are not fueled or defueled within the building.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0314, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0314, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0314, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0314, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0315 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0315, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-0315, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0319 Mobile food preparation vehicles.

319.1 General. Mobile food preparation vehicles that are equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems shall comply with this section.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0319, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0319, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0321 Artificial combustible vegetation.

321.1 Artificial combustible vegetation on roofs and near buildings. Artificial combustible vegetation exceeding 6 feet (1829 mm) in height and permanently installed outdoors within 5 feet (1524 mm) of a building or on the roof of a building shall comply with Section 807.4.1. The placement of artificial combustible vegetation shall also comply with Sections 806.3 and 807.4.2.

EXCEPTIONS: 1. Artificial decorative vegetation located more than 30 feet (9144 mm) from the exterior wall of a building.
2. Artificial decorative vegetation used at structures regulated by the International Residential Code.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0321, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0322 Lithium batteries.

322.1 General. The storage of lithium-ion and lithium metal batteries shall comply with Section 322.

EXCEPTIONS: 1. New or refurbished batteries installed in the equipment, devices, or vehicles they are designed to power.
2. New or refurbished batteries packed for use with the equipment, devices, or vehicles they are designed to power.
3. Batteries in original retail packaging that are rated at 300 watt-hours or less for lithium-ion batteries or contain 25 grams or less of lithium metal for lithium metal batteries.
4. Temporary storage of batteries or battery components during the battery manufacturing process prior to completion of final quality control checks.
5. Temporary storage of batteries during the vehicle manufacturing or repair process.

322.2 Permits. Permits shall be required for an accumulation of more than 15 cubic feet (0.42 m³) of lithium-ion and lithium metal batteries, other than batteries listed in the exceptions to Section 322.1, as set forth in Section 105.5.14.1.

322.3 Fire safety plan. A fire safety plan shall be provided in accordance with Section 403.10.6. In addition, the fire safety plan shall include emergency response actions to be taken upon detection of a fire or possible fire involving lithium-ion or lithium metal battery storage.

322.4 Storage requirements. Lithium-ion and lithium metal batteries shall be stored in accordance with Section 322.4.1, 322.4.2, or 322.4.3, as applicable.

322.4.1 Limited indoor storage in containers. Not more than 15 cubic feet (0.42 m³) of lithium-ion or lithium metal batteries shall be permitted to be stored in containers in accordance with the following:

1. Containers shall be open-top and constructed of noncombustible materials or shall be approved for battery collection.

2. Individual containers and groups of containers shall not exceed a capacity of 7.5 cubic feet (0.21 m³).

3. A second container or group of containers shall be separated by not less than 3 feet (914 mm) of open space, or 10 feet (3048 mm) of space that contains combustible materials.

4. Containers shall be located not less than 5 feet (1524 mm) from exits or exit access doors.

322.4.2 Indoor storage areas. Indoor storage areas for lithium-ion and lithium metal batteries, other than those complying with Section 322.4.1, shall comply with Sections 322.4.2.1 through 322.4.2.6.

322.4.2.1 Technical opinion and report. Where required by the *fire code official* a technical opinion and report complying with Section 104.8.2 shall be prepared to evaluate the fire and explosion risks associated with the indoor storage area and to make recommendations for fire and explosion protection. The report shall be submitted to the fire code official and shall require the fire code official's approval prior to issuance of a permit. In addition to the requirements of Section 104.8.2, the technical opinion and report shall specifically evaluate the following:

1. The potential for deflagration of flammable gases released during a thermal runaway event.

2. The basis of design for an automatic sprinkler system or other approved fire suppression system. Such design basis shall reference relevant full-scale fire testing or another approved method of demonstrating sufficiency of the recommended design.

322.4.2.2 Construction requirements. Where indoor storage areas for lithium-ion and lithium metal batteries are located in a building with other uses, battery storage areas shall be separated from the remainder of the building by 2-hour rated fire barriers or horizontal assemblies. Fire barriers shall be constructed in accordance with Section 707 of the International Building Code, and horizontal assemblies shall be constructed in accordance with Section 711 of the International Building Code.

EXCEPTIONS: 1. Where battery storage is contained in one or more approved prefabricated portable structures providing a complete two-hour fire resistance rated enclosure, fire barriers and horizontal assemblies are not required.
2. Where battery storage is limited to new batteries in packaging that has been demonstrated to and approved by the fire code official as sufficient to isolate a fire in packaging to the package interior, fire barriers and horizontal assemblies are not required.

322.4.2.3 Fire protection systems. Indoor storage areas for lithium-ion and lithium metal batteries shall be protected by an automatic sprinkler system complying with Section 903.3.1.1 or an approved alternative fire suppression system. The system design shall be based on recommendations in the approved technical opinion and report required by Section 322.4.2.1.

322.4.2.4 Fire alarm systems. Indoor storage areas for lithium-ion and lithium metal batteries shall be provided with an approved automatic fire detection and alarm system complying with Section 907. The fire detection system shall use air-aspirating smoke detection, radiant energy-sensing fire detection, or both.

322.4.2.5 Explosion control. Where the approved technical opinion and report required by Section 322.4.2.1 recommends explosion control, explosion control complying with Section 911 shall be provided.

322.4.2.6 Reduced requirements for storage of partially charged batteries. Indoor storage areas for lithium-ion and lithium metal batteries with a demonstrated state of charge not exceeding 30 percent shall not be required to comply with Section 322.4.2.1, 322.4.2.2, or 322.4.2.5, provided that procedures for limiting and verifying that the state of charge will not exceed 30 percent have been approved.

322.4.3 Outdoor storage. Outdoor storage of lithium-ion or lithium metal batteries shall comply with Sections 322.4.3.1 through 322.4.3.3.

322.4.3.1 Distance from storage to exposures. Outdoor storage of lithium-ion or lithium metal batteries, including storage beneath weather protection in accordance with Section 414.6.1 of the International Building Code, shall comply with one of the following:

1. Battery storage shall be located not less than 20 feet (6096 mm) from any building, lot line, public street, public alley, public way, or means of egress.

2. Battery storage shall be located not less than 3 feet (914 mm) from any building, lot line, public street, public alley, public way, or means of egress, where the battery storage is separated by a 2-hour fire-resistance rated assembly without openings or penetrations and extending 5 feet (1524 mm) above and to the sides of the battery storage area.

3. Battery storage shall be located not less than 3 feet (914 mm) from any building, lot line, public street, public alley, public way, or means of egress, where batteries are contained in approved prefabricated portable structures providing a complete 2-hour fire-resistance rated enclosure.

322.4.3.2 Storage area size limits and separation. Outdoor storage areas for lithium-ion or lithium metal batteries, including storage beneath weather-protection in accordance with Section 414.6.1 of the International Building Code, shall not exceed 900 sq. ft. (83.6 m²). The height of battery storage in such areas shall not exceed 10 feet (3048 mm). Multiple battery storage areas shall be separated from each other by not less than 10 feet (3048 mm) of open space.

322.4.3.3 Fire detection. Outdoor storage areas for lithium-ion or lithium metal batteries, regardless of whether such areas are open, under weather protection or in a prefabricated portable structure, shall be provided with an approved automatic fire detection and alarm system complying with Section 907. The fire detection system shall use radiant energy-sensing fire detection.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0322, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0322, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0323 Powered micromobility devices and powered industrial trucks.

323.1 General. Lithium-ion and lithium metal battery powered micromobility devices and powered industrial trucks shall be operated and maintained in accordance with this section.

EXCEPTIONS: 1. Storage, repair and charging in residential occupancies of powered mobility devices, provided that such devices are for personal use by its *owner*.
 2. Charging of a single powered mobility device in any occupancy by its *owner*.

323.1.1 Prohibited locations. The use of a residential occupancy as a business for the charging of commercially owned powered mobility devices or powered industrial trucks as part of a rental or sales service shall not be permitted.

323.2 Battery chargers and equipment. Powered micromobility devices and powered industrial trucks shall be charged in accordance with their listing and the manufacturer's instructions using only the original equipment manufacturer-supplied charging equipment or charging equipment in accordance with the listing and manufacturer's instructions.

323.3 Listing. Powered micromobility devices shall be listed and labeled in accordance with UL 2272 or UL 2849, as applicable.

323.4 Battery charging areas. Where approved, powered micromobility devices and powered industrial trucks shall be permitted to be charged in a room or area that complies with all of the following:

1. Only listed devices utilizing listed charging equipment shall be permitted to be charged.

2. Is provided with sufficient electrical receptacles to allow the charging equipment for each device to be directly connected to a receptacle. Extension cords and relocatable power taps shall not be used.

3. Storage of combustible materials, combustible waste or hazardous materials shall not be permitted.

4. The charging operation shall not be conducted in or obstruct any required means of egress.

5. Removable storage batteries shall not be stacked or charged in an enclosed cabinet unless the cabinet is specially designed and approved for such purpose.

6. A minimum distance of 18 inches (457.2 mm) shall be maintained between each removable storage battery during charging operations unless each battery is isolated from neighboring batteries by an approved fire-resistant material.

7. A minimum of 18 inches (457.2 mm) shall be maintained between the locations of the batteries on each powered micromobility devices or powered industrial truck during charging operations.

8. The indoor room or area shall be protected by a fire alarm system utilizing air-aspirating smoke detectors or radiant energy-sensing fire detection.

323.5 Fire safety plan. A fire safety plan shall be provided in accordance with Section 403.10.6. In addition, the fire safety plan shall include emergency response actions to be taken upon detection of a fire or possible fire involving lithium-ion or lithium metal battery storage.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0323, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0401 General.

401.2 Approval. Where required by the fire code official, fire safety plans, emergency procedures and employee training programs shall be approved by the fire official.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0401, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0401, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0402 Definitions. The following terms are defined in Chapter 2:

- ALARM SIGNAL;
- ALERT SIGNAL;
- ALERT SYSTEM;
- EMERGENCY EVACUATION DRILL;
- LOCKDOWN;
- SHELTER-IN-PLACE;
- RECALL SIGNAL.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0402, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-0402, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0402, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0403 Emergency preparedness requirements.

403.4.3 Assembly points and fire operations. Assembly points shall not be in areas likely to be utilized for fire service operations.

403.9.2 Group R-2 occupancies. Group R-2 occupancies shall comply with Sections 403.9.2.1 through 403.9.2.4.

403.9.2.4 Group R-2 assisted living and residential care facilities. Assisted living and residential care facilities licensed by the state of Washington shall comply with Section 403.7.1 as required for Group I-1 Condition 2 occupancies.

403.10.6 Buildings with lithium-ion or lithium metal battery storage. An approved fire safety plan in accordance with Section 404 shall be prepared and maintained for buildings with lithium-ion or lithium metal battery storage.

403.11.3 Crowd managers for gatherings exceeding 1,000 people. Where facilities or events involve a gathering of more than 1,000 people, or as required by the fire code official, crowd managers shall be provided in accordance with Sections 403.11.3.1 through 403.11.3.3.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0403, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0403, filed 6/14/22, 6/7/23, and

9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-0403, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0404 Fire safety and evacuation plans.

404.2.3 Lockdown plans. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0404, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0404, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0405 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0405, filed 12/18/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0405, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0405, filed 1/16/16, effective 7/1/16; WSR 13-20-118, § 51-54A-0405, filed 10/1/13, effective 11/1/13. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0405, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0406 Employee training and response procedures.

406.1 General. Employees in the occupancies listed in Section 403 shall be trained in the emergency procedures described in their emergency plans. Training shall be based on these plans and as described in Sections 406.2 through 406.3.5.

406.2 Frequency. Employees shall receive training in the contents of the emergency plans and their duties as part of new employee orientation and at least annually thereafter. Records shall be kept and made available to the fire code official upon request.

406.3 Employee training program. Employees shall be trained in fire prevention, evacuation, sheltering-in-place, and fire safety in accordance with Sections 406.3.1 through 406.3.5.

406.3.4 Emergency lockdown training. This section is not adopted.

406.3.5 Emergency shelter-in-place training. Where a facility has a shelter-in-place plan, employees shall be trained on the alert and recall signals, communication system, location of emergency supplies, the use of the incident notification and alarm system, and their assigned duties and procedures in the event of an alarm or emergency.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0406, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0406, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0406, filed 1/20/21, effective 2/20/21. Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0406, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0406, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0406, filed 1/16/16, effective 7/1/16. Statutory

Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0406, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0408 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0408, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0408, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0501 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0501, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0501, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0503 Fire apparatus access roads.

503.1 Where required. Fire apparatus access roads shall be provided and maintained in accordance with locally adopted street, road, and access standards.

503.1.1 Buildings and facilities. This section is not adopted.

503.1.2 Additional access. This section is not adopted.

503.1.3 High-piled storage. This section is not adopted.

503.2 Specifications. This section is not adopted.

503.3 Marking. This section is not adopted.

503.4 Obstruction of fire apparatus access roads. This section is not adopted.

503.4.1 Traffic calming devices. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0503, filed 11/15/23, effective 3/16/24. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0503, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0507 Fire protection water supplies.

507.3 Fire flow. Fire flow requirements for buildings or portions of buildings and facilities shall be determined by an approved method.

EXCEPTIONS:

1. Fire flow is not required for structures under 500 square feet (46 m²) with a B, U or R-I occupancy where structures are at least 30 feet (9144 mm) from any other structure and are used only for recreation.
2. In rural and suburban areas in which adequate and reliable water supply systems do not exist, the fire *code official* is authorized to utilize NFPA 1142 or the *International Wildland-Urban Interface Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0507, filed 11/15/23, effective 3/16/24; WSR 16-03-055, § 51-54A-0507, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0507, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0508 Fire command center.

508.1.2 Separation. The fire command center shall be separated from the remainder of the building by not less than a 2-hour fire barrier constructed in accordance with Section 707 of the International Building Code or horizontal assembly constructed in accordance with Section 711 of the International Building Code, or both.

[Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0508, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0508, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0510 Emergency responder communication coverage.

510.1 Emergency responder communication coverage in new buildings. Approved in-building, *emergency responder communications enhancement system (ERCES)* for emergency responders shall be provided in all new buildings. In-building ERCES within the building shall be based on the existing coverage levels of the public safety communication systems utilized by the jurisdiction, measured at the exterior of the building. The *emergency responder communications enhancement system*, where required, shall be of a type determined by the fire code official and the frequency license holder(s). This section shall not require improvement of the existing public safety communication systems.

EXCEPTIONS:

1. Where approved by the building official and the fire code official, a wired communication system in accordance with Section 907.2.13.2 shall be permitted to be installed or maintained instead of an approved communication coverage system.
2. Where it is determined by the *fire code official* that the communication coverage system is not needed.
3. In facilities where emergency responder communication coverage is required and such systems, components or equipment required could have a negative impact on the normal operations of that facility, the *fire code official* shall have the authority to accept an automatically activated *emergency responder communication coverage system*.

510.2 Emergency responder communication enhancement system in existing buildings. Existing buildings shall be provided with approved in-building, *emergency responder communications enhancement system* for emergency responders as required in Chapter 11.

510.3 Permit required. A construction permit for the installation of or modification to in-building, *emergency responder communication enhancement systems* and related equipment is required as specified in Section 105.6.4. Maintenance performed in accordance with this code is not considered a modification and does not require a permit.

510.4 Technical requirements. Equipment required to provide in-building, *emergency responder communication enhancement system* shall be listed in accordance with UL 2524. Systems, components and equipment required to provide the in-building, *emergency responder communication enhancement system* shall comply with Sections 510.4.1 through 510.4.2.8.

510.4.1 Emergency responder communication enhancement system signal strength. The building shall be considered to have an acceptable in-building, *emergency responder communication enhancement system* where signal strength measurements in 95 percent of all areas and 99 percent of areas designated as critical areas by the fire code official on each floor of the building meet the signal strength requirements in Sections 510.4.1.1 through 510.4.1.3.

510.4.1.1 Minimum signal strength into the building. The minimum in-bound signal strength shall be sufficient to provide usable voice communications throughout the coverage area as specified by the *fire code*

official. The inbound signal level shall be a minimum of -95 dBm in 95 percent of the coverage area and 99 percent in *critical areas* and sufficient to provide not less than a delivered audio quality (DAQ) of 3.0 or an equivalent signal-to-interference-plus-noise ratio (SINR) applicable to the technology for either analog or digital signals.

510.4.2 System design. The in-building, *emergency responder communication enhancement system* shall be designed in accordance with Sections 510.4.2.1 through 510.4.2.8 and NFPA 1221.

510.4.2.1 Amplification systems and components. Buildings and structures that cannot support the required level of in-building, *emergency responder communication enhancement system* shall be equipped with systems and components to enhance the radio signals and achieve the required level of in-building, *emergency responder communication enhancement system* specified in Sections 510.4.1 through 510.4.1.3. In-building, *emergency responder communication enhancement systems* utilizing radio-frequency-emitting devices and cabling shall be approved by the *fire code official*. Prior to installation, all RF-emitting devices shall have the certification of the radio licensing authority and be suitable for public safety use.

510.4.2.2 Technical criteria. The fire code official shall maintain a document providing the specific technical information and requirements for the in-building, *emergency responder communication enhancement system*. This document shall contain, but not be limited to, the various frequencies required, the location of radio sites, the effective radiated power of radio sites, the maximum propagation delay in microseconds, the applications being used and other supporting technical information necessary for system design.

510.4.2.3 Standby power. In-building, *emergency responder communication enhancement systems* coverage systems shall be provided with dedicated standby batteries or provided with 2-hour standby batteries and connected to the facility generator power system in accordance with Section 1203. The standby power supply shall be capable of operating the in-building, *emergency responder communication enhancement system* at 100 percent system capacity for a duration of not less than 12 hours.

510.4.2.4 Signal booster requirements. If used, signal boosters shall meet the following requirements:

1. All signal booster components shall be a National Electrical Manufacturer's Association (NEMA) 4, IP66-type waterproof cabinet or equivalent.

EXCEPTION: *Listed battery systems* that are contained in integrated battery cabinets.

2. Battery systems used for the emergency power source shall be contained in a NEMA 3R or higher-rated cabinet, IP65-type waterproof cabinet or equivalent.

EXCEPTION: *Listed battery systems* that are contained in integrated battery cabinets.

3. Equipment shall have FCC or other radio licensing authority certification and be suitable for public safety use prior to installation.

4. Where a donor antenna exists, isolation shall be maintained between the donor antenna and all inside antennas to not less than 20 dB greater than the system gain under all operating conditions.

5. Bi-directional amplifiers (BDA) used for in-building, *emergency responder communication enhancement systems* shall be fitted with anti-oscillation detection and control circuitry and per-channel AGC.

6. The installation of amplification systems or enhancement systems that operate on or provide the means to cause interference on any in-building, *emergency responder communication enhancement system* network shall be coordinated and approved by the fire code official.

7. Only channelized signal boosters shall be permitted.

EXCEPTION: Broadband BDAs may be utilized when specifically authorized in writing by the *frequency license holder*.

510.4.2.5 System monitoring. The in-building, *emergency responder communication enhancement system* shall include automatic supervisory and trouble signals that are monitored by a supervisory service and are annunciated by the *fire alarm system* in accordance with NFPA 72. The following conditions shall be separately annunciated by the *fire alarm system*, or, if the status of each of the following conditions is individually displayed on a dedicated panel on the in-building, *emergency responder communication enhancement system*, a single automatic supervisory signal may be annunciated on the *fire alarm system* indicating deficiencies of the in-building, *emergency responder communication enhancement system*:

1. Loss of normal AC power supply.
2. System battery charger(s) failure.
3. Malfunction of the donor antenna(s).
4. Failure of active RF-emitting device(s).
5. Low-battery capacity at 70 percent reduction of operating capacity.
6. Active system component malfunction.
7. Malfunction of the communications link between the *fire alarm system* and the in-building, *emergency responder communication enhancement system*.
8. Oscillation of active RF-emitting device(s).

510.4.2.6 Additional frequencies and change of frequencies. The in-building, *emergency responder communication enhancement system* shall be capable of modification or expansion in the event frequency changes are required by the FCC or other radio licensing authority, or additional frequencies are made available by the FCC or other radio licensing authority.

510.4.2.7 Design documents. The *fire code official* shall have the authority to require "as-built" design documents and specifications for in-building, *emergency responder communication enhancement systems*. The documents shall be in a format acceptable to the *fire code official*.

510.4.2.8 Radio communication antenna density. Systems shall be engineered to minimize the near-far effect. In-building, *emergency responder communication enhancement system* designs shall include sufficient antenna density to address reduced gain conditions.

EXCEPTION: Systems where all portable devices within the same band use active power control features.

510.5 Installation requirements. The installation of the in-building, *emergency responder communication enhancement system* shall be in accordance with NFPA 1221 and Sections 510.5.1 through 510.5.7.

510.5.1 Mounting of the donor antenna(s). To maintain proper alignment with the system designed donor site, donor antennas shall be permanently affixed on the highest possible position on the building or

where approved by the *fire code official*. A clearly visible sign stating "MOVEMENT OR REPOSITIONING OF THIS ANTENNA IS PROHIBITED WITHOUT APPROVAL FROM THE FIRE CODE OFFICIAL." shall be posted. The antenna installation shall be in accordance with the applicable requirements in the *International Building Code* for weather protection of the building envelope.

510.5.3 Minimum qualifications of personnel. The minimum qualifications of the system designer and lead acceptance test personnel shall include both of the following:

1. A valid FCC-issued general radio telephone operators license.
2. Certification of in-building system training issued by an approved organization or approved school, or a certificate issued by the manufacturer of the equipment being installed.

510.5.4 Acceptance test procedure. Where an in-building *emergency responder communication enhancement system* is required, and upon completion of installation, the building owner shall have the radio system tested to verify that two-way coverage on each floor of the building is in accordance with Section 510.4.1. The test procedure shall be conducted as follows:

1. Each floor of the building shall be divided into a grid of 20 approximately equal test areas, with a maximum test area size of 6,400 square feet (595 m²). Where the floor area exceeds 128,000 square feet (11,904 m²), the floor shall be divided into as many approximately equal test areas as needed, such that no test area exceeds the maximum square footage allowed for a test area.

2. The test shall be conducted using a calibrated portable radio of the latest brand and model used by the agency talking through the agency's radio communications system or equipment approved by the *fire code official*.

3. Coverage testing of signal strength shall be conducted using a calibrated spectrum analyzer for each of the test grids. A diagram of this testing shall be created for each floor where coverage is provided, indicating the testing grid used for the test in Section 510.5.4(1), and including signal strengths and frequencies for each test area. Indicate all critical areas.

4. Functional talk-back testing shall be conducted using two calibrated portable radios of the latest brand and model used by the agency's radio communications system or other equipment approved by the *fire code official*. Testing shall use digital audible quality (DAQ) metrics, where a passing result is a DAQ of 3 or higher. Communications between handsets shall be tested and recorded in the grid square diagram required by Section 510.5.3(2); each grid square on each floor; between each critical area and a radio outside the building; between each critical area and the fire command center or fire alarm control panel; between each landing in each stairwell and the fire command center or fire alarm panel.

5. Failure of more than 5 percent of the test areas on any floor shall result in failure of the test.

EXCEPTION: Critical areas shall be provided with 99 percent floor area coverage.

6. In the event that two of the test areas fail the test, in order to be more statistically accurate, the floor shall be permitted to be divided into 40 equal test areas. Failure of not more than two non-adjacent test areas shall not result in failure of the test. If the system fails the 40 area test, the system shall be altered to meet the 95 percent coverage requirement.

7. A test location approximately in the center of each test area shall be selected for the test, with the radio enabled to verify two-way communications to and from the outside of the building through the public agency's radio communications system. Once the test location has been selected, that location shall represent the entire test area. Failure in the selected test location shall be considered to be a failure of that test area. Additional test locations shall not be permitted.

8. The gain values of all amplifiers shall be measured and the test measurement results shall be kept on file with the building owner so that the measurements can be verified during annual tests. In the event that the measurement results become lost, the building owner shall be required to rerun the acceptance test to reestablish the gain values.

9. As part of the installation, a spectrum analyzer or other suitable test equipment shall be utilized to ensure spurious oscillations are not being generated by the subject signal booster. This test shall be conducted at the time of installation and at subsequent annual inspections.

10. Systems shall be tested using two portable radios simultaneously conducting subjective voice quality checks. One portable radio shall be positioned not greater than 10 feet (3048 mm) from the indoor antenna. The second portable radio shall be positioned at a distance that represents the farthest distance from any indoor antenna. With both portable radios simultaneously keyed up on different frequencies within the same band, subjective audio testing shall be conducted and comply with DAQ levels as specified in Sections 510.4.1.1 and 510.4.1.2.

11. **Documentation maintained on premises.** At the conclusion of the testing, and prior to issuance of the building certificate of occupancy, the building owner or owner's representative shall place a copy of the following records in the Distributed Antenna System enclosure or the building engineer's office. The records shall be available to the fire code official and maintained by the building owner for the life of the system:

a. A certification letter stating that the *emergency responder enhancement coverage system* has been installed and tested in accordance with this code, and that the system is complete and fully functional.

b. The grid square diagram created as part of testing in Sections 510.5.3(2) and 510.5.3(3).

c. Data sheets and/or manufacturer specifications for the *emergency responder enhancement coverage system* equipment; back up battery; and charging system (if utilized).

d. A diagram showing device locations and wiring schematic.

e. A copy of the electrical permit.

510.5.5 FCC compliance. The in-building, *emergency responder communication enhancement system* installation and components shall comply with all applicable federal regulations including, but not limited to, FCC 47 C.F.R. Part 90.219.

510.5.6 Wiring. The backbone, antenna distribution, radiating, or any fiber optic cables shall be rated as plenum cables. The backbone cables shall be connected to the antenna distribution, radiating, or copper cables using hybrid coupler devices of a value determined by the overall design. Backbone cables shall be routed through an enclosure that matches the building's required fire-resistance rating for

shafts or interior exit stairways. The connection between the backbone cable and the antenna cables shall be made within an enclosure that matches the building's fire-resistance rating for shafts or interior exit stairways, and passage of the antenna distribution cable in and out of the enclosure shall be protected as a penetration per the *International Building Code*.

510.5.7 Identification signs. *Emergency responder enhancement systems* shall be identified by an approved sign located on or near the fire alarm control panel or other approved location stating "This building is equipped with an *Emergency Responder Enhancement Coverage System*. Control Equipment located in or as approved by the *Fire Code Official*." A sign stating "*Emergency Responder Enhancement Coverage System Equipment*" shall be placed on or adjacent to the door of the room containing the main system components.

510.6 Maintenance. The in-building, *emergency responder communication enhancement system* shall be maintained operational at all times in accordance with Sections 510.6.1 through 510.6.4.

510.6.1 Testing and proof of compliance. The owner of the building or owner's authorized agent shall have the in-building, *emergency responder communication enhancement system* inspected and tested annually or where structural changes occur including additions or remodels that could materially change the original field performance tests. Testing shall consist of the following items 1 through 7:

1. In-building coverage test as required by the *fire code official* as described in Section 510.5.4 or 510.6.1.1.

EXCEPTION: Group R Occupancy annual testing is not required within *dwelling units*.

2. Signal boosters shall be tested to verify that the gain/output level is the same as it was upon initial installation and acceptance or set to optimize the performance of the system.

3. Backup batteries and power supplies shall be tested under load of a period of 1 hour to verify that they will properly operate during an actual power outage. If within the 1-hour test period the battery exhibits symptoms of failure, the test shall be extended for additional 1-hour periods until the integrity of the battery can be determined.

4. All other active components shall be checked to verify operation within the manufacturers specification.

5. If a fire alarm system is present in the building, a test shall be conducted to verify that the fire alarm system is properly supervising the *emergency responder communication enhancement system* as required in Section 510.4.2.5. The test is performed by simulating alarms to the fire alarm control panel. The certifications in Section 510.5.2 are sufficient for the personnel performing this testing.

6. At the conclusion of testing, a record of the inspection and maintenance along with an updated grid diagram of each floor showing tested strengths in each grid square and each critical area shall be added to the documentation maintained on the premises in accordance with Section 510.5.3.

7. At the conclusion of the testing, a report, which shall verify compliance with Section 510.6.1, shall be submitted to the *fire code official*.

510.6.1.1 Alternative in-building coverage test. When the comprehensive test documentation required by Section 510.5.3 is available, or the most recent full five-year test results are available if the sys-

tem is older than six years, the in-building coverage test required by the fire code official in Section 510.6.1(1), may be conducted as follows:

1. Functional talk-back testing shall be conducted using two calibrated portable radios of the latest brand and model used by the agency's radio communications system or other equipment approved by the fire code official. Testing shall use digital audible quality (DAQ) metrics, where a passing result is a DAQ of 3 or higher. Communications between handsets in the following locations shall be tested: Between the fire command center or fire alarm control panel and a location outside the building and between the fire alarm control panel and each landing in each stairwell.

2. Coverage testing of signal strength shall be conducted using a calibrated spectrum analyzer for:

- a. Three grid areas per floor. The three grid areas to be tested on each floor are the three grid areas with poorest performance in the acceptance test or the most recent annual test, whichever is more recent;

- b. Each of the critical areas identified in acceptance test documentation required by Section 510.5.3, or as modified by the fire code official; and

- c. One grid square per serving antenna.

3. The test area boundaries shall not deviate from the areas established at the time of the acceptance test, or as modified by the *fire code official*. The building shall be considered to have acceptable emergency responder communication coverage when the required signal strength requirements in Sections 510.4.1.1 and 510.4.1.2 are located in 95 percent of all areas on each floor of the building and 99 percent in critical areas, and any nonfunctional serving antenna are repaired to function within normal ranges. If the documentation of the acceptance test or most recent previous annual test results are not available or acceptable to the fire code official, the radio coverage verification testing described in Section 510.5.3 shall be conducted.

510.6.2 Additional frequencies. The building owner shall modify or expand the in-building, *emergency responder communication enhancement system* at their expense in the event frequency changes are required by the FCC or other radio licensing authority, or additional frequencies are made available by the FCC or other radio licensing authority. Prior approval of an in-building, *emergency responder communication enhancement system* on previous frequencies does not exempt this section.

510.6.3 Nonpublic safety system. Where other nonpublic safety amplification systems installed in buildings reduce the performance or cause interference with the in-building, *emergency responder communication enhancement system*, the nonpublic safety amplification system shall be corrected or removed.

510.6.4 Field testing. Agency personnel shall have the right to enter onto the property at any reasonable time to conduct field testing to verify the required level of radio coverage or to disable a system adversely impacting the *emergency responder communication enhancement system* in the region.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0510, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0510, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0510, filed

1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0510, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0605 Fuel fired appliances.

605.4.1.1 Approval. Outdoor fuel oil storage tanks shall be in accordance with UL 142, UL 142A, or UL 2085.

605.4.2.1 Approval. Indoor fuel oil storage tanks shall be in accordance with UL 80, UL 142, UL 142A, or UL 2085.

605.4.2.2 Quantity limits. One or more fuel oil storage tanks containing Class II or III combustible liquid shall be permitted in a building. The aggregate capacity of all tanks shall not exceed the following:

1. 660 gallons (2,498 L) in unsprinklered buildings, where stored in a tank complying with UL 80, UL 142, UL 142A, or UL 2085.

2. 1,320 gallons (4,996 L) in buildings equipped with an automatic sprinkler system in accordance with Section 903.3.1.1, where stored in a tank complying with UL 142 or UL 142A. The tank shall be listed as a secondary containment tank, and the secondary containment shall be monitored visually or automatically.

3. 3,000 gallons (11,356 L) in buildings equipped with an automatic sprinkler system in accordance with Section 903.3.1.1, where stored in protected above-ground tanks complying with UL 2085 and Section 5704.2.9.7. The tank shall be listed as a secondary containment tank, as required by UL 2085, and the secondary containment shall be monitored visually or automatically.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0605, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-0605, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 17-18-060, § 51-54A-0605, filed 9/1/17, effective 10/2/17. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0605, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0605, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27A and 34.05 RCW. WSR 13-24-076, § 51-54A-0605, filed 12/2/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0605, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0606 Section 606—Commercial cooking equipment and systems.

606.2 Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease laden vapors.

EXCEPTIONS:

1. Factory-built commercial exhaust hoods that are listed and labeled in accordance with UL 710, and installed in accordance with Section 304.1 of the *International Mechanical Code*, shall not be required to comply with Sections 507.1.5, 507.2.3, 507.2.5, 507.2.8, 507.3.1, 507.3.3, 507.4, and 507.5 of the *International Mechanical Code*.
2. Factory-built commercial cooking recirculating systems that are listed and labeled in accordance with UL 710B, and installed in accordance with Section 304.1 of the *International Mechanical Code*, shall not be required to comply with Sections 507.1.5, 507.2.3, 507.2.5, 507.2.8, 507.3.1, 507.3.3, 507.4, and 507.5 of the *International Mechanical Code*. Spaces in which such systems are located shall be considered to be kitchens and shall be ventilated in accordance with Table 403.3.1.1 of the *International Mechanical Code*. For the purpose of determining the floor area required to be ventilated, each individual appliance shall be considered as occupying not less than 100 square feet (9.3 m²).
3. Where cooking appliances are equipped with integral down-draft exhaust systems and such appliances and exhaust systems are listed and labeled for the application in accordance with NFPA 96, a hood shall not be required at or above them.

4. A Type I hood shall not be required for an electric cooking appliance where an approved testing agency provides documentation that the appliance effluent contains 5 mg/m³ or less of grease when tested at an exhaust flow rate of 500 cfm (0.236 m³/s) in accordance with UL 710B.
5. A Type I hood shall not be required to be installed in an R-2 occupancy with not more than 16 residents.

606.2.1 Domestic cooking appliances used for commercial purposes. Domestic cooking appliances utilized for commercial purposes shall be provided with Type I, Type II, or residential hoods as required for the type of appliances and processes in accordance with Table 606.2.1 and Sections 507.2 and 507.3 of the *International Mechanical Code*.

**Table 606.2.1
Type of Hood Required for Domestic
Cooking Appliances in the Following
Spaces^{a, b}**

Type of Space	Type of Cooking	Type of Hood
Church	1. Boiling, steaming, and warming precooked food	Residential hood ^c or Type II hood
	2. Roasting, pan frying, and deep frying	Type I hood
Community or party room in apartment and condominium	1. Boiling, steaming, and warming precooked food	Residential hood ^c or Type II hood ^d
	2. Roasting, pan frying, and deep frying	Type I hood
Day care	1. Boiling, steaming, and warming precooked food	Residential hood ^c or Type II hood ^d
	2. Roasting, pan frying, and deep frying	Type I hood
Dormitory, assisted living facility, nursing home	1. Boiling, steaming, and warming precooked food	Residential hood ^c or Type II hood
	2. Roasting, pan frying, and deep frying	Type I hood
Office lunch room	1. Boiling, steaming, and warming precooked food	Residential hood ^c or Type II hood ^d
	2. Roasting, pan frying, and deep frying	Type I hood

- ^a Commercial cooking appliances shall comply with Section 507.2 of the *International Mechanical Code*.
- ^b Requirements in this table apply to electric or gas fuel appliances only. Solid fuel appliances or charbroilers require Type I hoods.
- ^c Residential hood shall ventilate to the outside.

d Type II hood required when more than one appliance is used.

606.3 Operations, inspection, and maintenance. Commercial cooking systems shall be operated, inspected, and maintained in accordance with Sections 606.3.1 through 606.3.4 and Chapter 12 of NFPA 96.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0606, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0607 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0607, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0607, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-0607, filed 12/18/19, effective 7/1/20.]

WAC 51-54A-0609 Reserved.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0609, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0609, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0609, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0609, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0701 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0701, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-0701, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-0701, filed 1/2/19, effective 7/1/19.]

WAC 51-54A-0806 Decorative vegetation in new and existing buildings.

806.1.1 Restricted occupancies. Natural cut trees shall be prohibited in the following occupancies:

1. Group I; and
2. R-2 occupancies providing licensed care to clients in one of the categories listed in the International Building Code, Section 310.1, licensed by Washington state.

806.1.2 Support devices. The support device that holds the tree in an upright position shall be of a type that is stable and that meets all of the following criteria:

1. The device shall hold the tree securely and be of adequate size to avoid tipping over of the tree.

2. The device shall be capable of containing a minimum supply of water in accordance with Table 806.1.2.

3. The water level, when full, shall cover the tree stem at least 2 inches (51 mm). The water level shall be maintained above the fresh cut and checked at least once daily.

**Table 806.1.2
Support Stand Water Capacity**

Tree Stem Diameter (inches)	Minimum Support Stand Water Capacity (gallons)	Typical Daily Water Transpiration Amount (gallons)
Up to 4	1	1/4 to 1
4 to 6	1 1/2	1 1/4 to 1 1/2
7 to 8	2	1 3/4 to 2
9 to 12	3	2 1/4 to 3
13 and over	4	Over 3

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0806, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0901 General.

901.4.2 Nonrequired fire protection systems and life safety systems. A fire protection and life safety system or portion thereof not required by this code or the *International Building Code* shall be allowed to be furnished for partial or complete protection provided such installed system meets the applicable requirements of this code and the *International Building Code*. Such systems or portion of system shall be provided with signage stating "NON-REQUIRED SYSTEM." Signage shall be durable and permanent in nature, with contrasting color and background, and with lettering of not less than 1 inch (25 mm) in height. Location of such signage shall be approved.

901.8.2 Removal of existing occupant-use hose lines. The fire code official is authorized to permit the removal of existing occupant-use hose lines where all of the following conditions exist:

1. Installation is not required by this code, the *International Building Code*, or a previously approved alternative method.
2. The hose line would not be utilized by trained personnel or the fire department.
3. The remaining outlets are compatible with local fire department fittings.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0901, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0901, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-0901, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0903 Automatic sprinkler systems.

903.2 Where required. Approved automatic sprinkler systems in new buildings and structures shall be provided in the locations described in Sections 903.2.1 through 903.2.12.

EXCEPTIONS: 1. Spaces or areas in telecommunications buildings used exclusively for telecommunications equipment, associated electrical power distribution equipment, batteries and standby engines, provided that those spaces or areas are equipped throughout with an automatic smoke detection system in accordance with Section 907.2 and are separated from the remainder of the building by not less than 1-hour *fire barriers* constructed in accordance with Section 707 of the *International Building Code* or not less than 2-hour *horizontal assemblies* constructed in accordance with Section 711 of the *International Building Code*, or both.
2. Bottom of the elevator hoistway in an enclosed and noncombustible elevator shaft.

903.2.1.3 Group A-3. An automatic sprinkler system shall be provided throughout stories containing Group A-3 occupancies and throughout all stories from the Group A-3 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The fire area exceeds 12,000 square feet (1115 m²).
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.

EXCEPTION: For fixed guideway transit and passenger rail system stations, an automatic sprinkler system shall be provided in accordance with Section 4901.

903.2.1.6 Assembly occupancies on roofs. Where an occupied roof has an assembly occupancy with an occupant load exceeding 100 for Group A-2, and 300 for other Group A occupancies, the building shall be equipped with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or 903.3.1.2.

EXCEPTION: Open parking garages of Type I or Type II construction.

903.2.1.8 Nightclub. An automatic sprinkler system shall be provided throughout Group A-2 nightclubs as defined in this code.

903.2.3 Group E. An automatic sprinkler system shall be provided for fire areas containing Group E occupancies where the fire area has an occupant load of 51 or more, calculated in accordance with Table 1004.5.

EXCEPTIONS: 1. Portable school classrooms with an occupant load of 50 or less calculated in accordance with Table 1004.5, provided that the aggregate area of any cluster of portable classrooms does not exceed 6,000 square feet (557 m²); and clusters of portable school classrooms shall be separated as required by the building code; or
2. Portable school classrooms with an occupant load from 51 through 98, calculated in accordance with Table 1004.5, and provided with two means of direct independent exterior egress from each classroom in accordance with Chapter 10, and one exit from each classroom shall be accessible, provided that the aggregate area of any cluster of portable classrooms does not exceed 6,000 square feet (557 m²); and clusters of portable school classrooms shall be separated as required by the building code; or
3. Fire areas containing day care and preschool facilities with a total occupant load of 100 or less located at the level of exit discharge where every room in which care is provided has not fewer than one exit discharge door.

903.2.6 Group I. An *automatic sprinkler system* shall be provided throughout buildings with a Group I *fire area*.

EXCEPTIONS: 1. An *automatic sprinkler system* installed in accordance with Section 903.3.1.2 shall be permitted in Group I-1 Condition 1 facilities.
2. Where new construction or additions house less than 16 persons receiving care, an automatic sprinkler system installed in accordance with Section 903.2.8.3 shall be permitted for Group I-1, Condition 2, assisted living facilities licensed under chapter 388-78A WAC and residential treatment facilities licensed under chapter 246-337 WAC.
3. An automatic sprinkler system installed in accordance with Section 903.3.1.2 shall be permitted in additions to existing buildings where both of the following situations are true:
3.1. The addition is made to a building previously approved as Group LC or Group R-2 that houses either an assisted living facility licensed under chapter 388-78A WAC or residential treatment facility licensed under chapter 246-337 WAC.
3.2. The addition contains spaces for 16 or fewer persons receiving care.

903.2.6.1 Group I-4. An automatic sprinkler system shall be provided in fire areas containing Group I-4 occupancies where the fire area has an occupant load of 51 or more, calculated in accordance with Table 1004.5.

EXCEPTIONS: 1. An automatic sprinkler system is not required where Group I-4 day care facilities with a total occupant load of 100 or less, and located at the level of exit discharge and where every room where care is provided has not fewer than one exterior exit door.
2. In buildings where Group I-4 day care is provided on levels other than the level of exit discharge, an automatic sprinkler system in accordance with Section 903.3.1.1 shall be installed on the entire floor where care is provided, all floors between the level of care and the level of exit discharge and all floors below the level of exit discharge other than areas classified as an open parking garage.

903.2.8 Group R. An automatic sprinkler system installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R fire area.

- EXCEPTION: Group R-1 if all of the following conditions apply:
1. The Group R fire area is no more than 500 square feet (46 m²) and is used for recreational use only.
 2. The Group R fire area is on only one story.
 3. The Group R fire area does not include a basement.
 4. The Group R fire area is no closer than 30 feet (9144 mm) from another structure.
 5. Cooking is not allowed within the Group R fire area.
 6. The Group R fire area has an occupant load of no more than eight.
 7. A hand-held (portable) fire extinguisher is in every Group R fire area.

903.2.8.5 Adult family home. An adult family home with a capacity of seven or eight that serves residents who require assistance during an evacuation must install an automatic sprinkler system that meets the requirements of NFPA 13D.

903.2.11.1.3 Basements. Where any portion of a basement is located more than 75 feet (22,860 mm) from openings required by Section 903.2.11.1, or where new walls, partitions or other similar obstructions are installed that increase the exit access travel distance to more than 75 feet (22,860 mm), the basement shall be equipped throughout with an approved automatic sprinkler system.

903.2.11.5 Commercial cooking operations. An automatic sprinkler system shall be installed in commercial kitchen exhaust hood and duct systems where an automatic sprinkler system is used to comply with Section 904.

- EXCEPTION: An automatic fire sprinkler system is not required to protect the ductwork that is in excess of 75 feet (22,860 mm) when the commercial kitchen exhaust hood is protected by a system listed per UL 300.

**Table 903.2.11.6
Additional Required Fire Protection
Systems**

Note: Add section and subject to existing model code table.

Section	Subject
322.4.2.3	Lithium-ion and lithium metal battery storage

903.2.11.7 Relocatable buildings within buildings. Relocatable buildings or structures located within a building with an approved fire sprinkler system shall be provided with fire sprinkler protection within the occupiable space of the building and the space underneath the relocatable building.

- EXCEPTIONS:
1. Sprinkler protection is not required underneath the building when the space is separated from the adjacent space by construction resisting the passage of smoke and heat and combustible storage will not be located there.
 2. If the building or structure does not have a roof or ceiling obstructing the overhead sprinklers.
 3. Construction trailers and temporary offices used during new building construction prior to occupancy.
 4. Movable shopping mall kiosks with a roof or canopy dimension of less than 4 feet (1219 mm) on the smallest side.

903.3.1.2 NFPA 13R sprinkler systems. Automatic sprinkler systems in Group R occupancies up to and including four stories in height in buildings not exceeding 60 feet (18,288 mm) in height above grade plane shall be permitted to be installed throughout in accordance with NFPA 13R. The number of stories of Group R occupancies constructed in accordance with Sections 510.2 and 510.4 of the *International Building Code* shall be measured from the horizontal assembly creating separate buildings.

903.3.5.3 Underground portions of fire protection system water supply piping. The portion of the installation or modification of an underground water main, public or private, dedicated to supplying a water-

based fire protection system shall be in accordance with NFPA 24 and chapter 18.160 RCW. Piping and appurtenances downstream of the first control valve on the lateral or service line from the distribution main to 1 foot (305 mm) above finished floor shall be approved by the fire code official. Such underground piping shall be installed by a fire sprinkler system contractor licensed in accordance with chapter 18.160 RCW and holding either a Level U or a Level 3 license. For underground piping supplying systems installed in accordance with Section 903.3.1.2, a Level 2, 3, or U licensed contractor is acceptable.

EXCEPTIONS: 1. Portions of underground piping supplying automatic sprinkler systems installed in accordance with Section 903.3.1.3.
2. Portions of underground water mains serving sprinkler systems that are designed and installed in accordance with Section 903.3.1.2 and are less than 4 inches (100 mm) in nominal diameter.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0903, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0903, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0903, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0903, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0903, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0903, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.020, and 19.27.031. WSR 14-24-090, § 51-54A-0903, filed 12/1/14, effective 5/1/15. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0903, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0904 Alternative automatic fire-extinguishing systems.

904.1.1 Certification of service personnel for fire-extinguishing equipment. Service personnel performing system design, installation, or conducting system maintenance or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate ICC/NAFED certification.

904.1.1.1 Preengineered kitchen fire-extinguishing systems. A current ICC/NAFED certification for preengineered kitchen fire-extinguishing systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.2 Engineered fire suppression systems. A current ICC/NAFED certification for engineered fire suppression systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.3 Preengineered industrial fire-extinguishing system. A current ICC/NAFED certification for preengineered industrial fire-extinguishing system is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1 (Effective July 1, 2024) Certification of personnel for alternative fire-extinguishing equipment. Personnel performing system design, installation, maintenance, programming or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate National Institute for Certification in Engineering Technologies (NICET) *Special Hazards Suppression Systems* certification.

EXCEPTION: A current ICC/NAFED certification for preengineered kitchen fire extinguishing system technician is allowed in lieu of NICET Level II or higher in *Special Hazards Suppression Systems* for the design, installation, inspection/testing or maintenance on preengineered kitchen suppression systems.

904.1.1.1 (Effective July 1, 2024) Design. All construction documents shall be reviewed by a NICET Level III in special hazard suppression systems or a licensed professional engineer (PE) in the state of Washington prior to being submitted for permitting. The reviewing professional shall submit a stamped, signed, and dated letter; or a verification method approved by the *fire code official* indicating the system has been reviewed and meets or exceeds the design requirements of the state of Washington and the local jurisdiction.

904.1.1.2 (Effective July 1, 2024) Installation. Installation not defined as "electrical construction trade" by chapter 19.28 RCW or "Fire Protection Sprinkler Fitting" by chapter 18.270 RCW, shall be completed by or directly supervised by a NICET Level II or higher in *special hazards suppression systems*. Supervision shall consist of a person being on the same job site and under the control of a NICET Level II or higher in *special hazards suppression systems*.

904.1.1.3 (Effective July 1, 2024) Testing/maintenance. Inspection, testing, commissioning, maintenance, and programming not defined as "electrical construction trade" by chapter 19.28 RCW or "Fire Protection Sprinkler Fitting" by chapter 18.270 RCW, shall be completed by a NICET Level II or higher in *special hazards suppression systems*.

904.13 Commercial cooking systems. The automatic fire-extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Preengineered automatic dry- and wet-chemical extinguishing systems shall be tested in accordance with UL 300 and *listed* and *labeled* for the intended application. Other types of automatic fire-extinguishing systems shall be *listed* and *labeled* for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, NFPA 96, its listing and the manufacturer's installation instructions. Additional protection is not required for ductwork beyond 75 feet (22,860 mm) when hood suppression system complies with UL 300. Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved. Automatic fire-extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12.
2. *Automatic sprinkler systems*, NFPA 13.
3. Automatic water mist systems, NFPA 750.
4. Foam-water sprinkler system or foam-water spray systems, NFPA 16.
5. Dry-chemical extinguishing systems, NFPA 17.
6. Wet-chemical extinguishing systems, NFPA 17A.

EXCEPTIONS: 1. Factory-built commercial cooking recirculating systems that are tested in accordance with UL 710B and listed, labeled and installed in accordance with Section 304.1 of the *International Mechanical Code*.
2. Protection of duct systems beyond 75 feet (22,860 mm) when the commercial kitchen exhaust hood is protected by a system listed in accordance with UL 300.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0904, filed 11/15/23, effective 3/16/24; WSR 22-13-093,

23-12-107, and 23-20-027, § 51-54A-0904, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-0904, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0904, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0907 Fire alarm and detection systems.

907.2.3 Group E. Group E occupancies shall be provided with a manual fire alarm system that initiates the occupant notification signal utilizing one of the following:

1. An emergency voice/alarm communication system meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6; or

2. A system developed as part of a safe school plan adopted in accordance with RCW 28A.320.125 or developed as part of an emergency response system consistent with the provisions of RCW 28A.320.126. The system must achieve all of the following performance standards:

2.1 The ability to broadcast voice messages or customized announcements;

2.2 Includes a feature for multiple sounds, including sounds to initiate a lock down;

2.3 The ability to deliver messages to the interior of a building, areas outside of a building as designated pursuant to the safe school plan, and to personnel;

2.4 The ability for two-way communications;

2.5 The ability for individual room calling;

2.6 The ability for a manual override;

2.7 Installation in accordance with NFPA 72;

2.8 Provide 15 minutes of battery backup for alarm and 24 hours of battery backup for standby; and

2.9 Includes a program for annual inspection and maintenance in accordance with NFPA 72.

EXCEPTIONS:

1. A manual fire alarm system is not required in Group E occupancies with an occupant load of 50 or less.

2. Emergency voice/alarm communication systems meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6 shall not be required in Group E occupancies with occupant loads of 100 or less, such as individual portable school classroom buildings; provided that activation of the manual fire alarm system initiates an approved occupant notification signal in accordance with Section 907.5.

3. Where an existing approved alarm system is in place, an emergency voice/alarm system is not required in any portion of an existing Group E building undergoing any one of the following repairs, alteration or addition:

3.1 Alteration or repair to an existing building including, without limitation, alterations to rooms and systems, and/or corridor configurations, not exceeding 35 percent of the fire area of the building (or the fire area undergoing the alteration or repair if the building is comprised of two or more fire areas); or

3.2 An addition to an existing building, not exceeding 35 percent of the fire area of the building (or the fire area to which the addition is made if the building is comprised of two or more fire areas).

4. Manual fire alarm boxes are not required in Group E occupancies where all of the following apply:

4.1 Interior corridors are protected by smoke detectors.

4.2 Auditoriums, cafeterias, gymnasiums and similar areas are protected by heat detectors or other approved detection devices.

4.3 Shops and laboratories involving dusts or vapors are protected by heat detectors or other approved detection devices.

5. Manual fire alarm boxes shall not be required in Group E occupancies where all of the following apply:

5.1 The building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1.

5.2 The emergency voice/alarm communication system will activate on sprinkler waterflow.

5.3 Manual activation is provided from a normally occupied location.

907.2.3.1 Sprinkler systems or detection. When automatic sprinkler systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

907.2.6.1 Group I-1. An automatic smoke detection system shall be installed in *corridors*, waiting areas open to *corridors* and *habitable spaces* other than *sleeping units* and *kitchens*. The system shall be activated in accordance with Section 907.4.

EXCEPTIONS:

1. For Group I-1 Condition 1 occupancies, smoke detection in *habitable spaces* is not required where the facility is equipped throughout with an *automatic sprinkler system* installed in accordance with Section 903.3.1.1.

2. Smoke detection is not required for exterior balconies.

907.2.6.4 Group I-4 occupancies. A manual fire alarm system that initiates the occupant notification signal utilizing an emergency voice/ alarm communication system meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6 shall be installed in Group I-4 occupancies. When automatic sprinkler systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

EXCEPTIONS: 1. A manual fire alarm system is not required in Group I-4 occupancies with an occupant load of 50 or less.
2. Emergency voice alarm communication systems meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6 shall not be required in Group I-4 occupancies with occupant loads of 100 or less, provided that activation of the manual fire alarm system initiates an approved occupant notification signal in accordance with Section 907.5.

907.2.11.1 Group R-1. Single or multiple-station smoke alarms shall be installed in all of the following locations in Group R-1:

1. In sleeping areas.
2. In each *loft* constructed in accordance with Section 420.13 of the *International Building Code*.
3. In every room in the path of the means of egress from the sleeping area to the door leading from the sleeping unit.
4. In each story within the sleeping unit, including basements. For sleeping units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

907.2.11.2 Groups R-2, R-3, R-4, and I-1. Single- or multiple-station smoke alarms shall be installed and maintained in Groups R-2, R-3, R-4, and I-1 regardless of occupant load at all of the following locations:

1. On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms.
2. In each room used for sleeping purposes.
3. In each *loft* constructed in accordance with Section 420.13 of the *International Building Code*.
4. In each story within a *dwelling unit*, including *basements* but not including crawl spaces and uninhabitable attics. In *dwellings* or *dwelling units* with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

907.5.2.1.2 Maximum sound pressure. The maximum sound pressure level for audible alarm notification appliances shall be 110 dBA at the minimum hearing distance from the audible appliance. For systems operating in public mode, the maximum sound pressure level shall not exceed 30 dBA over the average ambient sound level. Where the average ambient noise is greater than 95 dBA, visible alarm notification appliances shall be provided in accordance with NFPA 72 and audible alarm notification appliances shall not be required.

907.8.4.1 Testing/maintenance: All inspection, testing, maintenance and programming not defined as "*electrical construction trade*" by chapter 19.28 RCW shall be completed by a NICET II or ESA/NTS Certified Fire Alarm Technician (CFAT) Level II Fire in fire alarms (effective July 1, 2018).

907.11 NICET: National Institute for Certification in Engineering Technologies and ESA/NTS: Electronic Security Association/National Training School.

907.11.1 Scope. This section shall apply to new and existing fire alarm systems.

907.11.2 Design review: All construction documents shall be reviewed by a NICET III, an ESA/NTS Certified Fire Alarm Designer (CFAD) Level III Fire in fire alarms, or a licensed professional engineer (PE) in Washington prior to being submitted for permitting. The reviewing professional shall submit a stamped, signed, and dated letter; or a verification method approved by the local authority having jurisdiction indicating the system has been reviewed and meets or exceeds the design requirements of the state of Washington and the local jurisdiction (effective July 1, 2018).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0907, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0907, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0907, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-0907, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-0907, filed 1/2/19, effective 7/1/19. Statutory Authority: RCW 19.27.074 and 19.27.550. WSR 18-01-104, § 51-54A-0907, filed 12/19/17, effective 7/1/18. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0907, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0907, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.020, and 19.27.031. WSR 14-24-091, § 51-54A-0907, filed 12/1/14, effective 5/1/15. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0907, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0908 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0908, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27, 19.27A, and 34.05 RCW. WSR 13-24-017, § 51-54A-0908, filed 11/21/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0908, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0909 Section 909—Smoke control systems.

909.21.12 Hoistway venting. Hoistway venting need not be provided for pressurized elevator shafts.

909.21.13 Machine rooms. Elevator machine rooms shall be pressurized in accordance with this section unless separated from the hoistway shaft by construction in accordance with Section 707 of the *International Building Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0909, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0909, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-0909, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0909, filed

1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0909, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0913 Section 913—Fire pumps.

913.2.1 Protection of fire pump rooms and access. Fire pumps shall be located in rooms that are separated from all other areas of the building by 2-hour fire barriers constructed in accordance with Section 707 of the *International Building Code* or 2-hour horizontal assemblies constructed in accordance with Section 711 of the *International Building Code*, or both. Fire pump rooms not directly accessible from the outside shall be accessible through an enclosed passageway from an interior exit stairway or exterior exit. The enclosed passageway shall have a *fire-resistance rating* not less than the *fire-resistance rating* of the fire pump room (see NFPA 20 Section 4.14.2.1.2).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0913, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-0915 Carbon monoxide detection.

915.1.1 Where required. Carbon monoxide detection shall be provided in Group I and R occupancies and in classrooms in Group E occupancies in the locations specified in Section 915.2 where any of the conditions in Sections 915.1.2 through 915.1.6 exist.

EXCEPTIONS: 1. R-2 occupancies, with the exception of R-2 college dormitories, are required to install carbon monoxide detectors without exception.
2. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, DOC prisons and work releases and assisted living facilities and residential treatment facilities licensed by the state of Washington, which do not themselves contain a fuel-burning appliance, a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that they comply with the exceptions of Section 915.1.4.

915.2.1 Dwelling units. Carbon monoxide detection shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms and on each level of the dwelling. Where a fuel-burning appliance or a fuel-burning fireplace is located within a bedroom or its attached bathroom, carbon monoxide detection shall be installed within the bedroom.

915.2.3 Group E occupancies. When required by Section 915.1 in new buildings, or by Chapter 11 of the *International Fire Code*, carbon monoxide detection shall be installed in classrooms in Group E occupancies. Carbon monoxide alarm signals shall be automatically transmitted to an on-site location that is staffed by school personnel.

EXCEPTIONS: 1. Carbon monoxide alarm signals shall not be required to be automatically transmitted to an on-site location that is staffed by school personnel in Group E occupancies with an occupant load of 50 or less.
2. Carbon monoxide alarm signals shall not be required to be automatically transmitted to an on-site location that is staffed by school personnel in Group E occupancies where an exception contained in Section 915.1 applies, or in Group E occupancies where signals are transmitted to an off-site service monitored by a third party, such as a service that monitors fire protection systems in the building.

915.5.1 General. Carbon monoxide detection systems shall comply with NFPA 72. Carbon monoxide detectors shall be listed in accordance with UL 2075.

915.5.2 Locations. Carbon monoxide detectors shall be installed in the locations specified in Section 915.2. These locations supersede the locations specified in NFPA 72.

915.6 Maintenance. Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0915, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-0915, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0915, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0915, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0916 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0916, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0916, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0918 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0918, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-0918, filed 12/18/19, effective 7/1/20.]

WAC 51-54A-1003 General means of egress.

1003.7 Elevators, escalators, and moving walks. Elevators, escalators, and moving walks shall not be used as a component of a required means of egress from any other part of the building.

- EXCEPTIONS:
1. Elevators used as an accessible means of egress in accordance with Section 1009.4.
 2. Escalators used as a means of egress for fixed transit and passenger rail systems in accordance with Section 4901.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1003, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1003, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1004 Occupant load.

1004.5 Areas without fixed seating. The number of occupants shall be computed at the rate of one occupant per unit of area as prescribed in Table 1004.5. For areas without fixed seating, the occupant load shall be not less than that number determined by dividing the floor area under consideration by the occupant load factor assigned to the function of the space as set forth in Table 1004.5. Where an intended function is not listed in Table 1004.5, the *fire code official* shall establish a function based on a listed function that most nearly resembles the intended function.

- EXCEPTION:
- Where approved by the fire code official, the actual number of occupants for whom each occupied space, floor, or building is designed, although less than those determined by calculation, shall be permitted to be used in the determination of the design occupant load.

1004.5.1 Increased occupant load. The occupant load permitted in any building, or portion thereof, is permitted to be increased from that number established for the occupancies in Table 1004.5, provided that all other requirements of the code are met based on such modified number and the occupant load does not exceed one occupant per 7 square feet (0.65 m²) of occupiable floor space. Where required by the *fire code official*, an approved aisle, seating or fixed equipment diagram substantiating any increase in occupant load shall be submitted. Where required by the *fire code official*, such diagram shall be posted.

**Table 1004.5
Maximum Floor Area Allowances Per Occupant**

Function of Space	Occupant Load Factor^a
Accessory storage areas, mechanical equipment room	300 gross
Agricultural building	300 gross
Aircraft hangars	500 gross
Airport terminal	
Baggage claim	20 gross
Baggage handling	300 gross
Concourse	100 gross
Waiting areas	15 gross
Assembly	
Gaming floors (keno,slots, etc.)	11 gross
Exhibit gallery and museum	30 net
Billiard table/game table area	50 gross
Assembly with fixed seats	See Section 1004.6
Assembly without fixed seats	
Concentrated (chairs only - Not fixed)	7 net
Standing space	5 net
Unconcentrated (tables and chairs)	15 net
Bowling centers, allow 5 persons for each lane including 15 feet of runway and for additional areas	7 net
Business areas	150 gross
Concentrated business use areas	See Section 1004.8
Courtrooms - Other than fixed seating areas	40 net
Day care	35 net
Dormitories	50 gross
Educational	
Classroom area	20 net
Shops and other vocational room areas	50 net
Exercise rooms	50 gross
Fixed guideway transit and passenger rail systems	
Platform	100 gross (See Section 4901)
Concourse/lobby	
Group H-5 fabrication and manufacturing areas	200 gross
Industrial areas	100 gross
Institutional areas	
Inpatient treatment areas	240 gross
Outpatient areas	100 gross
Sleeping areas	120 gross
Kitchens, commercial	200 gross
Library	

Function of Space	Occupant Load Factor ^a
Reading rooms Stack area	50 net 100 gross
Locker rooms	50 gross
Mall buildings - Covered and open	See Section 402.8.2 of the IBC
Mercantile Storage, stock, shipping areas	60 gross 300 gross
Parking garages	200 gross
Residential	200 gross
Skating rinks, swimming pools Rink and pool Decks	50 gross 15 gross
Stages and platforms	15 net
Warehouses	500 gross
For SI: 1 foot = 304.8 mm, 1 square foot = 0.0929 m ²	

^a Floor area in square feet per occupant.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1004, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1005 Means of egress sizing.

1005.1 General. All portions of the *means of egress* system shall be sized in accordance with this section.

EXCEPTIONS: 1. Aisles and aisle access ways in rooms or spaces used for assembly purposes complying with Section 1030.
2. The capacity in inches, of means of egress components for fixed guideway transit and passenger rail stations, shall meet the requirements of Section 4901.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1005, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1006 Number of exits and exit access doorways.

1006.2.1 Egress based on occupant load and common path of egress travel distance. Two *exits* or *exit access doorways* from any space shall be provided where the design occupant load or the common path of egress travel distance exceeds the values listed in Table 1006.2.1. The cumulative *occupant load* from adjacent rooms, areas or spaces shall be determined in accordance with Section 1004.2.

EXCEPTIONS: 1. The number of *exits* from foyers, lobbies, vestibules or similar spaces need not be based on cumulative *occupant loads* for areas discharging through such spaces, but the capacity of the *exits* from such spaces shall be based on applicable cumulative occupant loads.
2. Care suites in Group I-2 occupancies complying with Section 407.4 of the *International Building Code*.
3. Unoccupied mechanical rooms and penthouses are not required to comply with the common path of egress travel distance measurement.
4. The common path of travel for fixed transit and passenger rail system stations shall be in accordance with Section 4901.

1006.2.1.1 Three or more exits or exit access doorways. Three *exits* or *exit access doorways* shall be provided from any space with an occupant load of 501 to 1,000. Four *exits* or *exit access doorways* shall be provided from any space with an occupant load greater than 1,000.

EXCEPTION: The number of required exits for fixed transit and passenger rail systems may be reduced by one at open stations.

1006.3.4 Single exits. A single exit or access to a single exit shall be permitted from any story or occupied roof where one of the following conditions exists:

1. The *occupant load*, number of *dwelling units* and *exit access* travel distance within the portion of the building served by the single exit do not exceed the values in Table 1006.3.4(1) or 1006.3.4(2).

2. Rooms, areas and spaces complying with Section 1006.2.1 with exits that discharge directly to the exterior at the level of *exit discharge*, are permitted to have one exit or access to a single exit.

3. Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit.

4. Groups R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit.

5. Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the *dwelling unit* provided that both of the following criteria are met:

5.1. The *dwelling unit* complies with Section 1006.2.1 as a space with one *means of egress*.

5.2. Either the exit from the *dwelling unit* discharges directly to the exterior at the level of *exit discharge*, or the *exit access* outside the dwelling unit's entrance door provides access to not less than two approved independent exits.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1006, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1006, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1007 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1007, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1007, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1008 Means of egress illumination.

1008.2.3 Exit discharge. This subsection is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1008, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-1008, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1008, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1009 Accessible means of egress.

1009.1 Accessible means of egress required. Accessible *means of egress* shall comply with this section. Accessible spaces shall be provided with not less than one accessible *means of egress*. Where more than one *means of egress* is required by Section 1006.2 or 1006.3 from any *accessible space*, each *accessible* portion of the space shall be served by not less than two *accessible means of egress*.

EXCEPTIONS: 1. One *accessible means of egress* is required from an *accessible mezzanine level* in accordance with Section 1009.3, 1009.4 or 1009.5.

2. In assembly areas with ramped *aisles* or stepped *aisles* one *accessible means of egress* is permitted where the *common path of egress travel* is *accessible* and meets the requirements in Section 1030.8.
3. In parking garages, *accessible means of egress* are not required to serve parking areas that do not contain accessible parking spaces.

1009.8 Two-way communication. A two-way communication system complying with Sections 1009.8.1 and 1009.8.2 shall be provided at the landing serving each elevator or bank of elevators on each accessible floor that is one or more stories above or below the *level of exit discharge*.

- EXCEPTIONS:
1. Two-way communication systems are not required at the landing serving each elevator or bank of elevators where the two-way communication system is provided within *areas of refuge* in accordance with Section 1009.6.5.
 2. Two-way communication systems are not required on floors provided with *ramps* that provide a direct path of egress travel to grade or the level of exit discharge conforming to the provisions of Section 1012.
 3. Two-way communication systems are not required at the landings serving only service elevators that are not designated as part of the *accessible means of egress* or serve as part of the required *accessible route* into a facility.
 4. Two-way communication systems are not required at the landings serving only freight elevators.
 5. Two-way communication systems are not required at the landing serving a private residence elevator.
 6. Two-way communication systems are not required in Group I-2 or I-3 facilities.

1009.8.1 System requirements. Two-way communication systems shall provide communication between each required location and the *fire command center* or a central control point location *approved* by the fire department. Where the central control point is not a *constantly attended location*, the two-way communication system shall have a timed automatic telephone dial-out capability that provides two-way communication with an approved supervising station. The two-way communication system shall include both audible and visible signals. The two-way communication system shall have a battery backup or an approved alternate source of power that is capable of 90 minutes use upon failure of the normal power source.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1009, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-1009, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-1009, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1009, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1010 Doors, gates and turnstiles.

1010.2.4 Locks and latches. Locks and latches shall be permitted to prevent operation of doors where any of the following exists:

1. Places of detention or restraint.
2. In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M, and S, and in places of religious worship, the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided:
 - 2.1. The locking device is readily distinguishable as locked;
 - 2.2. A readily visible sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED. The sign shall be in letters 1 inch (25 mm) high on a contrasting background; and
 - 2.3. The use of the key-operated locking device is revocable by the building official for due cause.
3. Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts has no doorknob or surface-mounted hardware.
4. Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be

equipped with a night latch, dead bolt, or security chain, provided such devices are openable from the inside without the use of a key or a tool.

5. Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures.

6. Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof.

7. Approved, listed locks without delayed egress shall be permitted in Group I-1 condition 2 assisted living facilities licensed under chapter 388-78A WAC and Group I-1 Condition 2 residential treatment facilities licensed under chapter 246-337 WAC by the state of Washington, provided that:

7.1. The clinical needs of one or more patients require specialized security measures for their safety.

7.2. The doors unlock upon actuation of the automatic sprinkler system or automatic fire detection system.

7.3. The doors unlock upon loss of electrical power controlling the lock or lock mechanism.

7.4. The lock shall be capable of being deactivated by a signal from a switch located in an approved location.

7.5. There is a system, such as a keypad and code, in place that allows visitors, staff persons and appropriate residents to exit. Instructions for exiting shall be posted within 6 feet of the door.

8. Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following:

8.1. The occupant load of the occupied exterior area shall not exceed 300 as determined by IBC Section 1004.

8.2. The maximum occupant load shall be posted where required by Section 1004.9. Such sign shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways.

8.3. A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side.

8.4. The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device.

8.5. A clear window or glazed door opening, not less than 5 square feet (0.46 m²) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area.

8.6. A readily visible durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating: THIS DOOR TO REMAIN UNLOCKED WHEN THE OUTDOOR AREA IS OCCUPIED. The letters on the sign shall be not less than 1 inch high on a contrasting background.

9. Locking devices are permitted on doors to balconies, decks, or other exterior spaces serving individual dwelling or sleeping units.

10. Locking devices are permitted on doors to balconies, decks, or other exterior spaces of 250 square feet or less, serving a private office space.

1010.2.14 Controlled egress doors in Groups I-1 and I-2. Electric locking systems, including electromechanical locking systems and elec-

tromagnetic locking systems, shall be permitted to be locked in the means of egress in Group I-1 or I-2 occupancies where the clinical needs of persons receiving care require their containment. Controlled egress doors shall be permitted in such occupancies where the building is equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or an approved automatic smoke or heat detection system installed in accordance with Section 907, provided that the doors are installed and operate in accordance with all of the following:

1. The doors shall unlock on actuation of the automatic sprinkler system or automatic smoke detection system.

2. The door locks shall unlock on loss of power controlling the lock or lock mechanism.

3. The door locking system shall be installed to have the capability of being unlocked by a switch located at the fire command center, a nursing station or other approved location. The switch shall directly break power to the lock.

4. A building occupant shall not be required to pass through more than one door equipped with a controlled egress locking system before entering an exit.

5. The procedures for unlocking the doors shall be described and approved as part of the emergency planning and preparedness required by Chapter 4 of the *International Fire Code*.

6. There is a system, such as a keypad and code, in place that allows visitors, staff persons and appropriate residents to exit. Instructions for exiting shall be posted within 6 feet of the door.

7. All clinical staff shall have the keys, codes or other means necessary to operate the locking systems.

8. Emergency lighting shall be provided at the door.

9. The door locking system units shall be listed in accordance with UL 294.

EXCEPTIONS:

1. Items 1 through 4 and 6 shall not apply to doors to areas where persons, which because of clinical needs, require restraint or containment as part of the function of a psychiatric treatment area.

2. Items 1 through 4 and 6 shall not apply to doors to areas where a listed egress control system is utilized to reduce the risk of child abduction from nursery and obstetric areas of a Group I-2 hospital.

1010.3.4 Security grilles. In Groups B, F, M and S, horizontal sliding or vertical security grilles are permitted at the main exit and shall be openable from the inside without the use of a key or special knowledge or effort during periods that the space is occupied. The grilles shall remain secured in the full-open position during the period of occupancy by the general public. Where two or more *exits* or *access to exits* are required, not more than one-half of the *exits* or *exit access doorways* shall be equipped with horizontal sliding or vertical security grilles.

1010.3.4.1 Fixed transit and passenger rail systems. In fixed transit and passenger rail system stations horizontal and vertical security grilles are permitted at station entrances as a component in the means of egress when the station is under constant supervision by on-site security personnel and an exit door with panic hardware that swings in the direction of egress, with a minimum clear width of 32 inches (813 mm), provided within 10 feet of the gate. The security grilles shall remain secured in the full-open position during the period of occupancy by the general public.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1010, filed 11/15/23, effective 3/16/24; WSR 22-13-093,

23-12-107, and 23-20-027, § 51-54A-1010, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-1010, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-1010, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-1010, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1010, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1011 Stairways.

1011.17 Stairways in individual dwelling units. Stairs or ladders within an individual dwelling unit used for access to areas of 200 square feet (18.6 m²) or less, and not containing the primary bathroom or kitchen, are exempt from the requirements of Section 1009.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1011, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1012 Ramps.

1012.1 Scope. The provisions of this section shall apply to ramps used as a component of a means of egress.

EXCEPTIONS:

1. Other than ramps that are part of the accessible routes providing access in accordance with Sections 1108.2 through 1108.6 of the *International Building Code* ramped aisles within assembly rooms or spaces shall conform with the provisions in Section 1030.
2. Curb ramps shall comply with ICC A117.1.
3. Vehicle ramps in parking garages for pedestrian exit access shall not be required to comply with Sections 1012.3 through 1012.10 of the *International Building Code* when they are not an accessible route serving accessible parking spaces or other required accessible elements.
4. In a parking garage where one accessible means of egress serving accessible parking spaces or other accessible elements is provided, a second accessible means of egress serving that area may include a vehicle ramp that does not comply with Sections 1012.5, 1012.6, and 1012.9 of the *International Building Code*. A landing complying with Sections 1012.6.1 and 1012.6.4 of the *International Building Code* shall be provided at any change of direction in the accessible means of egress.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1012, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-1012, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1014 Section 1014—Handrails.

1014.2 Height and location. Handrails serving flights of stairways, ramps, stepped aisles, and ramped aisles shall comply with the provisions of Sections 1014.2.1 and 1014.2.2.

1014.2.1 Height. *Handrail* height, measured above stair tread nosings, or finish surface of ramp slope, shall be uniform, not less than 34 inches (864 mm) and not more than 38 inches (965 mm). *Handrail* height of alternating tread devices and ships ladders, measured above tread nosings, shall be uniform, not less than 30 inches (762 mm) and not more than 34 inches (864 mm).

EXCEPTIONS:

1. Where *handrail* fittings or bendings are used to provide continuous transition between flights, the fittings or bendings shall be permitted to exceed the maximum height.
2. In Group R-3 occupancies; within *dwelling units* in Group R-2 occupancies; and in Group U occupancies that are associated with a Group R-3 occupancy or associated with individual *dwelling units* in Group R-2 occupancies; where *handrail* fittings or bendings are used to provide continuous transition between flights, transition at *winder* treads, transition from *handrail* to guard, or where used at the start of a *flight*, the *handrail* height at the fittings or bendings shall be permitted to exceed the maximum height.
3. *Handrails* on top of a *guard* where permitted along stepped *aisles* and ramped *aisles* in accordance with Section 1030.16.

1014.2.2 Lateral location. Handrails located outward from the edge of the walking surface of flights of stairways, ramps, stepped aisles,

and ramped aisles shall be located within 6 inches (152 mm) measured horizontally from the edge of the walking surface. Handrails projecting into the width of the walking surface shall comply with Section 1014.8.

1014.8 Projections. On ramps and on ramped aisles that are part of an accessible route, the clear width between handrails shall be 36 inches (914 mm) minimum. Projections into the required width of stepped and ramped aisles, flights of stairways and ramps at each side shall not exceed 4.5 inches (114 mm) at or below the handrail height. Projections into the required width shall not be limited above the minimum headroom height required in Section 1011.3. Projections due to intermediate handrails shall not constitute a reduction in the egress width. Where a pair of intermediate handrails are provided within the stairway width without a walking surface between the pair of intermediate handrails and the distance between the pair of intermediate handrails is greater than 6 inches (152 mm), the available egress width shall be reduced by the distance between the closest edges of each such intermediate pair of handrails that is greater than 6 inches (152 mm).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1014, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-1015 Section 1015—Guards.

1015.2 Where required. *Guards* shall be located along open-sided walking surfaces, including mezzanines, equipment platforms, lofts in accordance with Section 420.14 of the International Building Code, aisles, stairs, ramps, and landings that are located more than 30 inches (762 mm) measured vertically to the floor or grade below at any point within 36 inches (914 mm) horizontally to the edge of the open side. *Guards* shall be provided at the perimeter of the occupied portions of an occupied roof. *Guards* shall be adequate in strength and attachment in accordance with Section 1607.9 of the International Building Code.

EXCEPTION:

Guards are not required for the following locations:

1. On the loading side of loading docks or piers.
2. On the audience side of stages and raised platforms, including stairs leading up to the stage and raised platforms.
3. On raised stage and platform floor areas, such as runways, ramps, and side stages used for entertainment or presentations.
4. At vertical openings in the performance area of stages and platforms.
5. At elevated walking surfaces appurtenant to stages and platforms for access to and utilization of special lighting or equipment.
6. Along vehicle service pits not accessible to the public.
7. In assembly seating areas at cross aisles in accordance with Section 1030.17.2.
8. On the loading side of station platforms on fixed guideway transit or passenger rail stations.
9. Portions of an occupied roof located less than 30 inches measured vertically to adjacent unoccupied roof areas when approved guards are present at the perimeter of the roof.
10. At an occupied portion of an occupied roof where a barrier approved by the building official is provided.

1015.3 Height. Required guards shall be not less than 42 inches (1067 mm) high, measured vertically as follows:

1. From the adjacent walking surfaces.
2. On *stairways* and *stepped aisles*, from the line connecting the leading edges of the tread nosings.
3. On *ramps* and *ramped aisles*, from the ramp surface at the *guard*.

EXCEPTIONS:

1. For occupancies in Group R-3 not more than three stories above grade in height and within individual *dwelling units* in occupancies in Group R-2 not more than three stories above grade in height with separate *means of egress*, required *guards* shall be not less than 36 inches (914 mm) in height measured vertically above the adjacent walking surfaces.
2. For occupancies in Group R-3, and within individual *dwelling units* in occupancies in Group R-2, *guards* on the open sides of *stairs* shall have a height not less than 34 inches (864 mm) measured vertically from a line connecting the leading edges of the treads.

3. For occupancies in Group R-3, and within individual *dwelling units* in occupancies in Group R-2, where the top of the *guard* serves as a *handrail* on the open sides of *stairs*, the top of the *guard* shall be not less than 34 inches (864 mm) and not more than 38 inches (965 mm) measured vertically from a line connecting the leading edges of the treads.
4. In areas with ceiling heights of 7 feet (2134 mm) or less in *lofts* constructed in accordance with Section 420.14, *guards* shall not be less than 36 inches (914 mm) in height or one-half of the clear height from the *loft* floor to the *loft* ceiling, whichever is less.
5. The *guard* height in assembly seating areas shall comply with Section 1030.17 as applicable.
6. Along *alternating tread devices* and ships ladders, *guards* where the top rail serves as a *handrail* shall have height not less than 30 inches (762 mm) and not more than 34 inches (864 mm), measured vertically from the leading edge of the device tread nosing.
7. In Group F occupancies where *exit access stairways* serve fewer than three stories and such *stairways* are not open to the public, and where the top of the *guard* also serves as a *handrail*, the top of the *guard* shall be not less than 34 inches (864 mm) and not more than 38 inches (965 mm) measured vertically from a line connecting the leading edges of the treads.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1015, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-1017 Exit access travel distance.

**Table 1017.2
Exit Access Travel Distance^a**

Occupancy	Without Sprinkler System (feet)	With Sprinkler System (feet)
A, E, F-1, M, R, S-1	200 ^c	250 ^b
I-1	Not Permitted	250 ^b
B	200	300 ^c
F-2, S-2, U	300	400 ^c
H-1	Not Permitted	75 ^d
H-2	Not Permitted	100 ^d
H-3	Not Permitted	150 ^d
H-4	Not Permitted	175 ^d
H-5	Not Permitted	200 ^c
I-2, I-3	Not Permitted	200 ^c
I-4	150	200 ^c

For SI: 1 foot = 304.8 mm.

- ^a See the following sections for modifications to exit access travel distance requirements:
 - Section 402.8 of the *International Building Code*: For the distance limitation in malls.
 - Section 407.4 of the *International Building Code*: For the distance limitation in Group I-2.
 - Sections 408.6.1 and 408.8.1 of the *International Building Code*: For the distance limitations in Group I-3.
 - Section 411.2 of the *International Building Code*: For the distance limitation in special amusement areas.
 - Section 412.6 of the *International Building Code*: For the distance limitations in aircraft manufacturing facilities.
 - Section 1006.2.2.2: For the distance limitation in refrigeration machinery rooms.
 - Section 1006.2.2.3: For the distance limitation in refrigerated rooms and spaces.
 - Section 1006.3.4: For buildings with one exit.
 - Section 1017.2.2: For increased distance limitation in Groups F-1 and S-1.
 - Section 1030.7: For increased limitation in assembly seating.
 - Section 3103.4 of the *International Building Code*: For temporary structures.
 - Section 3104.9 of the *International Building Code*: For pedestrian walkways.
 - Section 4901: For fixed guideway and passenger rail stations.
- ^b Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.
- ^c Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.
- ^d Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1.
- ^e Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1017, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1017, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1018 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1018, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1018, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1019 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1019, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1019, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1020 Corridors.

1020.6 Air movement in corridors. Corridors shall not serve as supply, return, exhaust, relief or ventilation air ducts.

EXCEPTIONS:

1. Use of a corridor as a source of makeup air for exhaust systems in rooms that open directly onto such corridors, including toilet rooms, bathrooms, dressing rooms, smoking lounges and janitor closets, shall be permitted provided that each such corridor is directly supplied with outdoor air at a rate greater than the rate of makeup air taken from the corridor.
2. Where located within a dwelling unit, the use of corridors for conveying return air shall not be prohibited.
3. Where located within tenant spaces of 1,000 square feet (93 m²) or less in area, utilization of corridors for conveying return air is permitted.
4. Incidental air movement from pressurized rooms within health care facilities, provided that a corridor is not the primary source of supply or return to the room.
5. Where such air is part of an engineered smoke control system.
6. Air supplied to corridors serving residential occupancies shall not be considered as providing ventilation air to the dwelling units subject to the following:
 - 6.1. The air supplied to the corridor is 100 percent outside air; and
 - 6.2. The units served by the corridor have conforming ventilation air independent of the air supplied to the corridor; and
 - 6.3. For other than high-rise buildings, the supply fan will automatically shut off upon activation of corridor smoke detectors which shall be spaced at no more than 30 feet (9144 mm) on center along the corridor; or
 - 6.4. For high-rise buildings, corridor smoke detector activation will close required smoke/fire dampers at the supply inlet to the corridor at the floor receiving the alarm.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1020, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-1020, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1021 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1021, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1021, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1023 Section 1023—Interior exit stairways and ramps.

1023.12 Smokeproof enclosures. Where required by Section 403.5.4, 405.7.2 or 412.2.2.1, of the *International Building Code*, interior exit stairways and ramps shall be smokeproof enclosures in accordance with Section 909.20 of the *International Building Code*. Where interior exit stairways and ramps are pressurized in accordance with Section 909.20.5 of the *International Building Code*, the smoke control pressurization system shall comply with the requirements specified in Section 909.6.3 of the *International Building Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1023, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1028 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-1028, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-1028, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1030 Reserved.

[Statutory Authority: Chapter 19.27 RCW. WSR 17-10-023, § 51-54A-1030, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1030, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1103 Fire safety requirements for existing buildings.

1103.2 Emergency responder communication enhancement in existing buildings. Existing buildings other than Group R-3, that do not have approved in-building, emergency response communication enhancement system for emergency responders in the building based on existing coverage levels of the public safety communication systems, shall be equipped with such coverage according to one of the following:

1. Where an existing wired communication system cannot be repaired or is being replaced, or where not approved in accordance with Section 510.1, Exception 1.
2. Within a time frame established by the adopting authority.

EXCEPTION: Where it is determined by the fire code official that the in-building, emergency responder communication enhancement system is not needed.

1103.4.3 More than five stories. In other than Group I occupancies, interior vertical openings connecting more than five stories shall be protected by fire-resistant and smoke-rated construction.

- EXCEPTIONS:
1. Vertical opening protection is not required for Group R-3 occupancies.
 2. Vertical opening protection is not required for open parking garages and ramps.
 3. Vertical opening protection for escalators shall be in accordance with Section 1103.4.8.

1103.5.6 Nightclub. An automatic sprinkler system shall be provided throughout A-2 nightclubs as defined in this code. No building shall be constructed for, used for, or converted to occupancy as a nightclub except in accordance with this section.

1103.9 Carbon monoxide alarms. Existing Group I or Group R occupancies shall be provided with single station carbon monoxide alarms in accordance with Section 915.4.3. An inspection will occur when alterations, repairs or additions requiring a permit occur, or when one or more sleeping rooms are added or created. The carbon monoxide alarms shall be listed as complying with UL 2034 and be installed and maintained in accordance with NFPA 72 and the manufacturer's instructions.

- EXCEPTIONS:
1. For other than R-2 occupancies, if the building does not contain a fuel-burning appliance, a fuel-burning fireplace, or an attached garage.
 2. Work involving the exterior surfaces of dwellings, such as the replacement of roofing or siding, or the addition or replacement of windows or doors, or the addition of a porch or deck, or electrical permits.
 3. Installation, alteration or repairs of noncombustion plumbing or mechanical systems.

4. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, DOC prisons and work releases and assisted living facilities and residential treatment facilities licensed by the state of Washington which do not themselves contain a fuel-burning appliance, a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that:

4.1. The sleeping units or dwelling unit is not adjacent to any room which contains a fuel-burning appliance, a fuel-burning fireplace, or an attached garage; and

4.2. The sleeping units or dwelling unit is not connected by duct work or ventilation shafts with a supply or return register in the same room to any room containing a fuel-burning appliance, a fuel-burning fireplace, or to an attached garage; and

4.3. The building is provided with a common area carbon monoxide detection system.

5. An open parking garage, as defined in the International Building Code, or enclosed parking garage ventilated in accordance with Section 404 of the International Mechanical Code shall not be considered an attached garage.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1103, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-1103, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27, 19.27A, and 34.05 RCW. WSR 13-24-017, § 51-54A-1103, filed 11/21/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1103, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1104 Means of egress for existing buildings.

1104.1 General. Means of egress in existing buildings shall comply with Section 1032 and 1104.2 through 1104.25.

EXCEPTION: Means of egress conforming to the requirements of the building code under which they were constructed and Section 1032 shall not be required to comply with 1104.2 through 1104.22 and 1104.25.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1104, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1104, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-05-065, § 51-54A-1104, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1104, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1105 Construction requirements for existing Group I-2.

1105.1 General. This section shall be applied by jurisdictions conducting surveys for compliance with the federal centers for medicare and medicaid reimbursement program. Existing Group I-2 shall meet all of the following requirements:

1. The minimum fire safety requirements in Section 1103.
2. The minimum means of egress requirements in Section 1104.
3. The additional egress and construction requirements in Section 1105.

Where the provisions of this chapter conflict with the construction requirements that applied at the time of construction, the most restrictive provisions shall apply.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1105, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1201 General.

1201.1 Scope. The provisions of this chapter shall apply to the installation, operation, maintenance, repair, retrofitting, testing,

commissioning and decommissioning of energy systems used for generating or storing energy including, but not limited to, energy storage systems under the exclusive control of an electric utility or lawfully designated agency. It shall not apply to equipment associated with the generation, control, transformation, transmission, or distribution of energy installations that is under the exclusive control of an electric utility or lawfully designated agency. Energy storage systems regulated by WAC 51-54A-1207 shall comply with this chapter as appropriate and NFPA 855.

1201.3 Mixed system installation. Where mixed systems are approved, the aggregate nameplate kWh energy of all energy storage systems in a fire area shall not exceed the maximum quantity specified for any of the energy systems in this chapter. Where required by the fire code official, a hazard mitigation analysis shall be provided and approved in accordance with Section 104.8.2 to evaluate any potential adverse interaction between the various energy systems and technologies.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-22-119, § 51-54A-1201, filed 10/31/23, effective 3/15/24.]

WAC 51-54A-1204 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1204, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-1204, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-1204, filed 12/18/19, effective 7/1/20.]

WAC 51-54A-1205 Section 1205—Solar photovoltaic power systems.

1205.1 General. Installation, modification, or alteration of solar photovoltaic power systems shall comply with this section. Due to the emerging technologies in the solar photovoltaic industry, it is understood fire code officials may need to amend prescriptive requirements of this section to meet the requirements for firefighter access and product installations. Section 104.10 Alternative materials and methods of this code shall be considered when approving the installation of solar photovoltaic power systems. Solar photovoltaic power systems shall be installed in accordance with Sections 1205.2.1 through 1205.6, the *International Building Code*, and chapter 19.28 RCW.

1205.2.1 Solar photovoltaic systems for Group R-3 residential and buildings built under the *International Residential Code*. Solar photovoltaic systems for Group R-3 residential and buildings built under the *International Residential Code* shall comply with Sections 1205.2.1.1 through 1205.2.3.

- EXCEPTIONS:
1. Residential dwellings with an approved automatic fire sprinkler system installed.
 2. Residential dwellings with approved mechanical or passive ventilation systems.
 3. Where the fire code official determines that the slope of the roof is too steep for emergency access.
 4. Where the fire code official determines that vertical ventilation tactics will not be utilized.
 5. These requirements shall not apply to roofs where the total combined area of the solar array does not exceed 33 percent as measured in plan view of the total roof area of the structure, where the solar array will measure 1,000 sq. ft. or less in area, and where a minimum 18 inches unobstructed pathway shall be maintained along each side of any horizontal ridge.

1205.6 Size of solar photovoltaic array.

1. Each photovoltaic array shall be limited to 150 feet (45,720 mm) by 150 feet (45,720 mm). Multiple arrays shall be separated by a 3-foot wide (914 mm) clear access pathway.

2. Panels/modules shall be located up to the roof ridge where an alternative ventilation method approved by the fire *code official* has determined vertical ventilation techniques will not be employed.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1205, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1205, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-1206 Stationary fuel cell power systems.

1206.1 General. Stationary fuel cell power systems in new and existing occupancies shall comply with this section.

EXCEPTION: The temporary use of a fuel cell-powered electric vehicle to power a Group R-3 or R-4 building while parked shall comply with Section 1206.13.

1206.5 Residential use. Stationary fuel cell power systems shall not be installed in Group R-3 and R-4 buildings, or dwelling units associated with Group R-2 buildings unless they are specifically listed for residential use.

EXCEPTION: The temporary use of a fuel cell-powered electric vehicle to power a Group R-3 or R-4 building while parked shall comply with Section 1206.13.

1206.6.3 Gas detection systems. Stationary fuel cell power systems shall be provided with a gas detection system. Detection shall be provided in approved locations in the fuel cell power system enclosure, the exhaust system, or the room that encloses the fuel cell power system. The system shall be designed to activate at a flammable gas concentration of not more than 25 percent of the lower flammable limit (LFL).

1206.6.3.1 System activation. The activation of the gas detection system shall automatically:

1. Close valves between the gas supply and the fuel cell power system.
2. Shut down the fuel cell power system.
3. Initiate local audible and visible alarms in approved locations.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-22-119, § 51-54A-1206, filed 10/31/23, effective 3/15/24.]

WAC 51-54A-1207 Electrical energy storage systems.

1207.1 General. The provisions in this section are applicable to stationary and mobile electrical energy storage systems (ESS).

EXCEPTION: ESS in Group R-3 and R-4 occupancies not exceeding thresholds in Section 1207.11.4 shall comply with Section 1207.11 through 1207.11.9.

1207.1.1 Scope. ESS having capacities exceeding the values shown in Table 1207.1.1 shall comply with this section.

**TABLE 1207.1.1
Energy Storage System (ESS) Threshold Quantities**

Technology	Energy Capacity ^a
Capacitor ESS	3 kWh
Flow batteries ^b	20 kWh
Lead-acid batteries, all types	70 kWh ^c
Lithium-ion batteries	20 kWh
Sodium nickel chloride batteries	70 kWh
Nickel-cadmium batteries (Ni-Cd), Nickel Metal Hydride (Ni-MH), and Nickel Zinc (Ni-Zn) batteries	70 kWh
Nonelectrochemical ESS ^d	70 kWh
Other battery technologies	10 kWh
Other electrochemical ESS technologies	3 kWh
Zinc manganese dioxide batteries (Zn-MnO ₂)	70 kWh

For SI: 1 kilowatt-hour = 3.6 megajoules.

^a Energy capacity is the total energy capable of being stored (nameplate rating), not the usable energy rating. For units rated in amp-hours, kWh shall equal rated voltage times amp-hour rating divided by 1,000.

^b Shall include vanadium, zinc-bromine, polysulfide-bromide and other flowing electrolyte-type technologies.

^c Fifty gallons of lead-acid battery electrolyte shall be considered equivalent to 70 kWh.

^d Covers nonelectrochemical technologies such as flywheel and thermal ESS.

1207.1.1.1 Utilities and industrial applications. This section shall not apply to capacitors and capacitor equipment for electric utilities and industrial facilities used in applications such as flexible ac transmission (FACTS) devices, filter capacitor banks, power factor correction, and standalone capacitor banks for voltage correction and stabilization.

1207.1.1.2 Mobile ESS. Mobile ESS deployed at an electric utility substation or generation facility for 90 days or less shall not add to the threshold values in Table 1207.1.1 for the stationary ESS installation if both of the following conditions apply:

1. The mobile ESS complies with Section 1207.10.

2. The mobile ESS is only being used during periods in which the facility's stationary ESS is being tested, repaired, retrofitted, or replaced.

1207.1.3 Construction documents. The following information shall be provided with the permit application:

1. Location and layout diagram of the room or area in which the ESS is to be installed.

2. Details on the hourly fire-resistance ratings of assemblies enclosing the ESS.

3. The quantities and types of ESS to be installed.

4. Manufacturer's specifications, ratings, and documentation of the listings of each ESS and associated equipment.

5. Description of energy (battery) management systems and their operation.

6. Location and content of required signage.

7. Details on fire suppression, smoke or fire detection, thermal management, ventilation, exhaust, and deflagration venting systems, if provided.

8. Support arrangement associated with the installation, including any required seismic restraint.

9. A commissioning plan complying with Section 1207.2.1.

10. A decommissioning plan complying with Section 1207.2.3.

11. A fire safety and evacuation plan in accordance with Section 404.

1207.1.3.1 Utilities applicability. Plans and specifications associated with ESS owned and operated by electric utilities as a component of the electric grid that are considered critical infrastructure documents in accordance with the provisions of the North American Electric Reliability Corporation and other applicable governmental laws and regulations shall be made available to the fire code official for viewing based on the requirements of the applicable governmental laws and regulations.

1207.1.4 Hazard mitigation analysis. Failure modes and effects analysis (FMEA) or other *approved* hazard mitigation analysis shall be provided in accordance with Section 104.8.2 under any of the following conditions:

1. Where ESS technologies not specifically identified in Table 1207.1.1 are provided.

2. More than one ESS technology is provided in a single fire area where there is a potential for adverse interaction between technologies.

3. Where allowed as a basis for increasing maximum allowable quantities. See Section 1207.5.2.

4. Where flammable gases can be produced under abnormal conditions.

5. Where required by the fire code official to address a potential hazard with an ESS installation that is not addressed by existing requirements.

1207.1.4.1 Fault condition. The hazard mitigation analysis shall evaluate the consequences of the following failure modes. Only single failure modes shall be considered.

1. A thermal runaway condition in a single electrochemical ESS unit.

2. A mechanical failure of a nonelectrochemical ESS unit.

3. Failure of any battery (energy) management system or fire protection system within the ESS equipment that is not covered by the product listing failure mode effects analysis (FMEA).

4. Failure of any required protection system external to the ESS including, but not limited to, ventilation (HVAC), exhaust ventilation, smoke detection, fire detection, gas detection, or fire suppression system.

1207.1.4.2 Analysis approval. The fire code official is authorized to approve the hazardous mitigation analysis provided that the consequences of the hazard mitigation analysis demonstrate:

1. Fires will be contained within unoccupied ESS rooms or areas for the minimum duration of the fire-resistance-rated separations identified in Section 1207.7.4.

2. Fires involving the ESS will allow occupants or the general public to evacuate to a safe location.

1207.1.5 Large-scale fire test. Where required elsewhere in Section 1207, large-scale fire testing shall be conducted on a representative ESS in accordance with UL 9540A. The testing shall be conducted or witnessed and reported by an approved testing laboratory and show that a fire involving one ESS will not propagate to an adjacent ESS, and where installed within buildings, enclosed areas and walk-in units will be contained within the room, enclosed area or walk-in unit for

the duration of the test. The test report shall be provided to the fire code official for review and approval in accordance with Section 104.8.2.

1207.1.6.1 Fire mitigation personnel. Where, in the opinion of the fire code official, it is essential for public safety that trained personnel be on-site to respond to possible ignition or re-ignition of a damaged ESS, the system owner, agent, or lessee shall dispatch within 15 minutes one or more fire mitigation personnel to the premise, as required and approved, at their expense. These personnel shall remain on duty continuously after the fire department leaves the premise until the damaged energy storage equipment is removed from the premises, or earlier if the fire code official indicates the public safety hazard has been abated.

1207.2.1 Commissioning. Commissioning of newly installed ESS and existing ESS that have been retrofitted, replaced, or previously decommissioned and are returning to service shall be conducted prior to the ESS being placed in service in accordance with a commissioning plan that has been approved prior to initiating commissioning. The commissioning plan shall include the following:

1. A narrative description of the activities that will be accomplished during each phase of commissioning, including the personnel intended to accomplish each of the activities.

2. A listing of the specific ESS and associated components, controls, and safety-related devices to be tested, a description of the tests to be performed, and the functions to be tested.

3. Conditions under which all testing will be performed, which are representative of the conditions during normal operation of the system.

4. Documentation of the owner's project requirements and the basis of design necessary to understand the installation and operation of the ESS.

5. Verification that required equipment and systems are installed in accordance with the approved plans and specifications.

6. Integrated testing for all fire and safety systems.

7. Testing for any required thermal management, ventilation, or exhaust systems associated with the ESS installation.

8. Preparation and delivery of operation and maintenance documentation.

9. Training of facility operating and maintenance staff.

10. Identification and documentation of the requirements for maintaining system performance to meet the original design intent during the operation phase.

11. Identification and documentation of personnel who are qualified to service, maintain and decommission the ESS, and respond to incidents involving the ESS, including documentation that such service has been contracted for.

12. A decommissioning plan for removing the ESS from service, and from the facility in which it is located. The plan shall include details on providing a safe, orderly shutdown of energy storage and safety systems with notification to the code officials prior to the actual decommissioning of the system. The decommissioning plan shall include contingencies for removing an intact operational ESS from service, and for removing an ESS from service that has been damaged by a fire or other event.

EXCEPTIONS: Commissioning shall not be required for lead-acid and nickel-cadmium battery systems at facilities under the exclusive control of communications utilities that comply with NFPA 76 and operate at less than 50 VAC and 60 VDC. A decommissioning plan shall be provided and maintained where required by the fire code official.

1. Lead-acid and nickel-cadmium battery systems less than 50 VAC, 60 VDC that are in telecommunications facilities for installations of communications equipment under the exclusive control of communications utilities and located outdoors or in building spaces or walk-in units used exclusively for such installations that are in compliance with NFPA 76 shall be permitted to have a commissioning plan in compliance with recognized industry practices in lieu of complying with Section 1207.2.1.
2. Lead-acid and nickel-cadmium battery systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utilities, and located in building spaces or walk-in units used exclusively for such installations shall be permitted to have a commissioning plan in compliance with applicable governmental laws and regulations in lieu of developing a commissioning plan in accordance with Section 1207.2.1.

1207.3.1 Energy storage system listings. ESS shall be listed in accordance with UL 9540.

EXCEPTIONS:

1. Lead-acid and nickel-cadmium battery systems less than 50 VAC, 60 VDC in telecommunications facilities for installations of communications equipment under the exclusive control of communications utilities located outdoors or in building spaces used exclusively for such installations that are in compliance with NFPA 76.
2. Lead-acid and nickel-cadmium battery systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations.
3. Lead-acid battery systems in uninterruptible power supplies listed and labeled in accordance with UL 1778 and utilized for standby power applications.

1207.3.7.1 Retrofitting lead acid and nickel cadmium. Changing out or retrofitting of lead-acid and nickel-cadmium batteries in the following applications shall be considered repairs where there is no increase in system size or energy capacity greater than 10 percent of the original design.

1. At facilities under the exclusive control of communications utilities that comply with NFPA 76 and operate at less than 50 VAC and 60 VDC.
2. Battery systems used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations.
3. Batteries in uninterruptible power supplies listed and labeled in accordance with UL 1778 and used for standby applications only.

1207.5 Electrochemical ESS protection. The protection of electrochemical ESS shall be in accordance with Sections 1207.5.1 through 1207.5.8 where required by Sections 1207.7 through 1207.10.

**TABLE 1207.5
Maximum Allowable Quantities of
Electrochemical ESS**

Technology	Maximum Allowable Quantities ^a
Storage Batteries	
Flow batteries ^b	600 kWh
Lead-acid, all types	Unlimited
Lithium-ion	600 kWh
Sodium nickel chloride	600 kWh
Nickel-cadmium (Ni-Cd), Nickel metal hydride (Ni-MH) and nickel zinc (Ni-Zn)	Unlimited
Zinc manganese dioxide (Zn-MnO ₂)	Unlimited
Other battery technologies	200 kWh
Capacitors	

Technology	Maximum Allowable Quantities ^a
All types	20 kWh
Other Electrochemical ESS	
All types	20 kWh

For SI: 1 kilowatt hour = 3.6 megajoules.

^a For electrochemical ESS units rated in amp-hours, kWh shall equal rated voltage times the amp-hour rating divided by 1,000.

^b Shall include vanadium, zinc-bromine, polysulfide-bromide, and other flowing electrolyte-type technologies.

1207.5.1 Size and separation. Electrochemical ESS shall be segregated into groups not exceeding 50 kWh (180 mega-joules). Each group shall be separated a minimum of three feet (914 mm) from other groups and from walls in the storage room or area. The storage arrangements shall comply with Chapter 10.

- EXCEPTIONS:
1. Lead-acid and nickel-cadmium battery systems in facilities under the exclusive control of communications utilities and operating at less than 50 VAC and 60 VDC in accordance with NFPA 76.
 2. Lead-acid and nickel-cadmium systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations.
 3. Lead-acid battery systems in uninterruptible power supplies and labeled in accordance with UL 1778, utilized for standby power applications, and limited to not more than 10 percent of the floor area on the floor on which the ESS is located.
 4. The fire code official is authorized to approve larger capacities or smaller separation distances based on large-scale fire testing complying with Section 1207.1.5.

1207.5.3 Elevation. Electrochemical ESS shall not be located in the following areas:

1. Where the floor is located more than 75 feet (22,860 mm) above the lowest level of fire department vehicle access.
2. Where the floor is located below the lowest level of exit discharge.

- EXCEPTIONS:
1. Lead-acid and nickel-cadmium battery systems less than 50 VAC and 60 VDC installed in facilities under the exclusive control of communications utilities in accordance with NFPA 76.
 2. Lead-acid and nickel-cadmium systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations.
 3. Lead-acid battery systems in uninterruptible power supplies and labeled in accordance with UL 1778, utilized for standby power applications, and limited to not more than 10 percent of the floor area on the floor on which the ESS is located.
 4. Where approved, installations shall be permitted in underground vaults complying with NFPA 70, Article 450, Part III.
 5. Where approved by the fire code official, installations shall be permitted on higher and lower floors.

1207.5.4 Fire detection. An approved automatic smoke detection system or radiant energy-sensing fire detection system complying with Section 907.2 shall be installed in rooms, indoor areas, and walk-in units containing electrochemical ESS. An approved radiant energy-sensing fire detection system shall be installed to protect open parking garage and rooftop installations. Alarm signals from detection systems shall be transmitted to a central station, proprietary or remote station service in accordance with NFPA 72, or where approved to a constantly attended location.

EXCEPTION: Normally unoccupied, remote stand-alone telecommunications structures with a gross floor area of less than 1500 ft² (139 m²) utilizing lead-acid or nickel-cadmium batteries shall not be required to have a fire detection system installed.

1207.5.4.1 System status. Lead-acid and nickel-cadmium battery systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations shall be allowed to use the process control system to monitor the smoke or radiant energy-sensing fire detectors required in Section 1207.5.4.

1207.5.5 Fire suppression systems. Rooms and areas within buildings and walk-in units containing electrochemical ESS shall be protected by an automatic fire suppression system designed and installed in accordance with one of the following:

1. Automatic sprinkler systems, designed and installed in accordance with Section 903.3.1.1 for ESS units (groups) with a maximum stored energy capacity of 50 kWh, as described in Section 1207.5.1, shall be designed with a minimum density of 0.3 gpm/ft² (1.14 L/min) based over the area of the room or 2,500 square-foot (232 m²) design area, whichever is smaller, unless a lower density is approved based upon large-scale fire testing in accordance with Section 1207.1.5.

2. Automatic sprinkler system designed and installed in accordance with Section 903.3.1.1 for ESS units (groups) exceeding 50 kWh shall use a density based on large-scale fire testing complying with Section 1207.1.5.

3. The following alternative automatic fire-extinguishing systems designed and installed in accordance with Section 904, provided that the installation is approved by the fire code official based on large-scale fire testing complying with Section 1207.1.5:

3.1. NFPA 12, Standard on Carbon Dioxide Extinguishing Systems.

3.2. NFPA 15, Standard for Water Spray Fixed Systems for Fire Protection.

3.3. NFPA 750, Standard on Water Mist Fire Protection Systems.

3.4. NFPA 2001, Standard on Clean Agent Fire-Extinguishing Systems.

3.5. NFPA 2010, Standard for Fixed Aerosol Fire-Extinguishing Systems.

EXCEPTIONS:

1. Fire suppression systems for lead-acid and nickel-cadmium battery systems at facilities under the exclusive control of communications utilities that operate at less than 50 VAC and 60 VDC shall be provided where required by NFPA 76.

2. Lead-acid and nickel-cadmium systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations, shall not be required to have a fire suppression system installed.

3. Lead-acid battery systems in uninterruptible power supplies listed and labeled in accordance with UL 1778, utilized for standby power applications, which is limited to not more than 10 percent of the floor area on the floor on which the ESS is located, shall not be required to have a fire suppression system.

1207.6 Electrochemical ESS technology-specific protection. Electrochemical ESS installations shall comply with the requirements of this section in accordance with the applicable requirements of Table 1207.6.

**TABLE 1207.6
Electrochemical ESS Technology-Specific Requirements**

Compliance Required ^b		Battery Technology					Sodium nickel chloride	Other ESS and Battery Technologies ^b	Capacitor ESS ^b
Feature	Section	Lead-acid	Nickel cadmium (Ni-Cd), nickel metal hydride (Ni-MH) and nickel zinc (Ni-Zn)	Zinc manganese dioxide (ZnMnO ₂)	Lithium-ion	Flow			
Exhaust ventilation	1207.6.1	Yes	Yes	Yes	No	Yes	No	Yes	Yes
Explosion control	1207.6.3	Yes ^a	Yes ^a	Yes	Yes	No	Yes	Yes	Yes
Safety caps	1207.6.4	Yes	Yes	Yes	No	No	No	Yes	Yes
Spill control and neutralization	1207.6.2	Yes ^c	Yes ^c	Yes ^f	No	Yes	No	Yes	Yes
Thermal runaway	1207.6.5	Yes ^d	Yes ^d	Yes ^c	Yes ^c	No	Yes	Yes ^c	Yes

^a Not required for lead-acid and nickel-cadmium batteries at facilities under the exclusive control of communications utilities that comply with NFPA 76 and operate at less than 50 VAC and 60 VDC.

- b Protection shall be provided unless documentation acceptable to the fire code official is provided in accordance with Section 104.8.2 that provides justification why the protection is not necessary based on the technology used.
- c Applicable to vented-type (i.e., flooded) nickel-cadmium and lead-acid batteries.
- d Not required for vented-type (i.e., flooded) batteries.
- e The thermal runaway protection is permitted to be part of a battery management system that has been evaluated with the battery as part of the evaluation to UL 1973.
- f Not required for batteries with jelled electrolyte.

1207.6.3 Explosion control. Where required by Table 1207.6 or elsewhere in this code, explosion control complying with Section 911 shall be provided for rooms, areas, ESS cabinets, or ESS walk-in units containing electrochemical ESS technologies.

- EXCEPTIONS:
1. Where approved, explosion control is permitted to be waived by the fire code official based on large-scale fire testing complying with Section 1207.1.5 that demonstrates that flammable gases are not liberated from electrochemical ESS cells or modules.
 2. Where approved, explosion control is permitted to be waived by the fire code official based on documentation provided in accordance with Section 104.8 that demonstrates that the electrochemical ESS technology to be used does not have the potential to release flammable gas concentrations in excess of 25 percent of the LFL anywhere in the room, area, walk-in unit or structure under thermal runaway, or other fault conditions.
 3. Where approved, ESS cabinets that have no debris, shrapnel, or enclosure pieces ejected during large scale fire testing complying with Section 1207.1.5 shall be permitted in lieu of providing explosion control complying with Section 911.
 4. Explosion control is not required for lead-acid and nickel-cadmium battery systems less than 50 VAC, 60 VDC in telecommunication facilities under the exclusive control of communications utilities located in building spaces or walk-in units used exclusively for such installations.
 5. Explosion control is not required for lead-acid and nickel-cadmium systems used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility located in building spaces or walk-in units used exclusively for such installations.
 6. Explosion control is not required for lead-acid battery systems in uninterruptible power supplies listed and labeled in accordance with UL 1778, utilized for standby power applications, and housed in a single cabinet in a single fire area in buildings or walk-in units.

1207.10.1 Charging and storage. For the purpose of Section 1207.10, charging and storage covers the operation where mobile ESS are charged and stored so they are ready for deployment to another site, and where they are charged and stored after a deployment.

- EXCEPTION:
- Mobile ESS used to temporarily provide power to lead-acid and nickel-cadmium systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations.

1207.10.2 Deployment. For the purpose of Section 1207.10, deployment covers operations where mobile ESS are located at a site other than the charging and storage site and are being used to provide power.

- EXCEPTION:
- Mobile ESS used to temporarily provide power to lead-acid and nickel-cadmium systems that are used for dc power for control of substations and control or safe shutdown of generating stations under the exclusive control of the electric utility, and located outdoors or in building spaces used exclusively for such installations.

1207.11 ESS in Group R-3 and R-4 occupancies. ESS in Group R-3 and R-4 occupancies shall be in accordance with Sections 1207.11.1 through 1207.11.9.

- EXCEPTIONS:
1. ESS listed and labeled in accordance with UL 9540 and marked "For use in residential dwelling units", where installed in accordance with the manufacturer's instructions and NFPA 70.
 2. ESS rated less than 1 kWh (3.6 megajoules).

1207.11.1 Equipment listings. ESS shall be listed and labeled in accordance with UL 9540.

- EXCEPTIONS: Not adopted.

1207.11.2.1 Spacing. Individual ESS units shall be separated from each other by at least three feet (914 mm) except where smaller separation distances are documented to be adequate based on large-scale fire testing complying with Section 1207.1.5.

1207.11.3 Location. ESS shall be installed only in the following locations:

1. Detached garages and detached accessory structures.

2. Attached garages separated from the dwelling unit living space and sleeping units in accordance with Section 406.3.2 of the International Building Code.

3. Outdoors or on the exterior side of exterior walls located a minimum of three feet (914 mm) from doors and windows directly entering the dwelling unit.

4. Enclosed utility closets, basements, storage or utility spaces within dwelling units and sleeping units with finished or noncombustible walls and ceilings. Walls and ceilings of unfinished wood-framed construction shall be provided with not less than 5/8 in. Type X gypsum wallboard.

ESS shall not be installed in sleeping rooms, or closets or spaces opening directly into sleeping rooms.

1207.11.4 Energy ratings. Individual ESS units shall have a maximum rating of 20 kWh. The aggregate rating of the ESS shall not exceed:

1. 40 kWh within utility closets, basements, and storage or utility spaces.

2. 80 kWh in attached or detached garages and detached accessory structures.

3. 80 kWh on exterior walls.

4. 80 kWh outdoors on the ground.

ESS installations exceeding the permitted individual or aggregate ratings shall be installed in accordance with Sections 1207.1 through 1207.9.

1207.11.6 Fire detection. ESS installed in Group R-3 and R-4 occupancies shall comply with the following:

1. Rooms and areas within dwelling units, sleeping units, basements and attached garages in which ESS are installed shall be protected by smoke alarms in accordance with Section 907.2.11.

2. A listed heat alarm shall be installed in locations where smoke alarms cannot be installed based on their listing.

1207.11.7 Protection from impact. ESS installed in a location subject to vehicle damage shall be protected by approved barriers. Appliances in garages shall also be installed in accordance with Section 304.3 of the International Mechanical Code.

1207.11.8 Ventilation. Indoor installations of ESS that include batteries that produce hydrogen or other flammable gases during charging shall be provided with exhaust ventilation in accordance with Section 304.5 of the International Mechanical Code.

1207.11.9 Toxic and highly toxic gas. Model code section not adopted.

1207.11.10 Electric vehicle use. The temporary use of an owner or occupant's electric-powered vehicle to power a dwelling unit or sleeping unit while parked in an attached or detached garage or outdoors shall comply with the vehicle manufacturer's instructions and NFPA 70.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-22-119, § 51-54A-1207, filed 10/31/23, effective 3/15/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1207, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-2404 Spray finishing.

2404.2.1 Prohibited enclosures for spray application operations. Inflatable or portable enclosures shall not be used for spray application of flammable finishes.

EXCEPTION: Enclosures for the spray application of flammable finishes in marinas, dry docking areas, or construction areas shall comply with Section 2404.3.5.

2404.3.5 Membrane enclosures. The design, construction, protection, operation and maintenance of membrane enclosures shall be in accordance with NFPA 33.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-2404, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3103 Temporary tents and membrane structures.

3103.5 Use period. Temporary tents, air-supported, air-inflated or tensioned membrane structures are permitted to be erected for a period of less than 180 days within a 12-month period on a single premises. Such structures erected for 180 days or more within a 12-month period shall comply with the IBC.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-3103, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-3303 Administrative safety controls.

3303.1.1 Components of site safety plans. *Site safety plans* shall include the following as applicable:

1. Name and contact information of site safety director.
2. Documentation of the training of the site safety director and fire watch personnel.
3. Procedures for reporting emergencies.
4. Fire department vehicle access routes.
5. Location of fire protection equipment, including portable fire extinguishers, standpipes, fire department connections, and fire hydrants.
6. Smoking and cooking policies, designated areas to be used where approved, and signage locations in accordance with Section 3305.7.
7. Location and safety considerations for temporary heating equipment.
8. Hot work permit plan.
9. Plans for control of combustible waste material.
10. Locations and methods for storage and use of flammable and combustible liquids and other hazardous materials.
11. Provisions for site security.
12. Changes that affect this plan.
13. Other site-specific information required by the *fire code official*.

3303.2.1 Training. Training of fire watch and other responsible personnel in the use of fire protection equipment shall be the responsibility of the site safety director. Records of training shall be kept and made a part of the written plan for the site safety plan.

3303.3 Daily fire safety inspection. The site safety director shall be responsible for completion of a daily fire safety inspection at the project site. Each day, all *building* and outdoor areas shall be inspected to ensure compliance with the inspection list in this section. The results of each inspection shall be documented and maintained on-site until a certificate of occupancy has been issued. Documentation shall be immediately available on-site for presentation to the *fire code official* upon request.

1. Any contractors entering the site to perform *hot work* each day have been instructed in the *hot work* safety requirements in Chapter 35, and *hot work* is performed only in areas *approved* by the site safety director.

2. Temporary heating equipment is maintained away from combustible materials in accordance with the equipment manufacturer's instructions.

3. Combustible debris, rubbish and waste material is removed from the *building* in areas where work is not being performed.

4. Temporary wiring does not have exposed conductors.

5. *Flammable liquids* and other hazardous materials are stored in locations that have been approved by the site safety director when not involved in work that is being performed.

6. Fire apparatus access roads required by Section 3307 are maintained clear of obstructions that reduce the width of the usable roadway to less than 20 feet (6096 mm).

7. Fire hydrants are clearly visible from access roads and are not obstructed.

8. The location of fire department connections to standpipe and in-service sprinkler systems are clearly identifiable from the access road and such connections are not obstructed.

9. Standpipe systems are in service and continuous to the highest work floor, as specified in Section 3307.5.

10. Portable fire extinguishers are available in locations required by Sections 3306.6 and 3305.10.2.

3303.5 Fire watch. Where required by the *fire code official* or the site safety plan established in accordance with Section 3303.1, a fire watch shall be provided for building demolition and for building construction.

EXCEPTION: New construction that is built under the International Residential Code.

3303.5.1 Fire watch during construction. A fire watch shall be provided during nonworking hours for new construction that exceeds 40 feet (12,192 mm) in height above the lowest adjacent grade at any point along the building perimeter, for new multistory construction with an aggregate area exceeding 50,000 square feet (4645 m²) per story or as required by the fire code official.

3303.5.2 Fire watch personnel. Fire watch personnel shall be provided in accordance with this section.

3303.5.2.1 Duties. The primary duty of fire watch personnel shall be to perform constant patrols and watch for the occurrence of fire. The combination of fire watch duties and site security duties is acceptable.

3303.5.2.2 Training. Personnel shall be trained to serve as an on-site fire watch. Training shall include the use of portable fire extin-

guishers. Fire extinguishers and fire reporting shall be in accordance with Sections 3303.6 and 3306.6.

3303.5.2.3 Means of notification. Fire watch personnel shall be provided with not fewer than one *approved* means for notifying the fire department.

3303.5.3 Fire watch location and records. The fire watch shall include areas specified by the site safety plan established in accordance with Section 3303.

3303.5.4 Fire watch records. Fire watch personnel shall keep a record of all time periods of duty, including the log entry for each time the site was patrolled and each time a structure was entered and inspected. Records shall be made available for review by the *fire code official* upon request.

3303.6 Emergency telephone. Emergency telephone *facilities* with ready access shall be provided in an *approved* location at the construction site, or an *approved* equivalent means of communication shall be provided. The street address of the construction site and the emergency telephone number of the fire department shall be posted adjacent to the telephone. Alternatively, where an equivalent means of communication has been *approved*, the site address and fire department emergency telephone number shall be posted at the main entrance to the site, in guard shacks, and in the construction site office.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3303, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3303, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3304 Protection of combustible materials.

3304.1 Combustible debris, rubbish, and waste. Combustible debris, rubbish, and waste material shall comply with the requirements of Sections 3304.1.1 through 3304.2.

3304.1.1 Combustible waste material accumulation. Combustible debris, rubbish, and waste material shall not be accumulated within *buildings*.

3304.1.2 Combustible waste material removal. Combustible debris, rubbish, and waste material shall be removed from *buildings* at the end of each shift of work.

3304.1.3 Rubbish containers. Where rubbish containers with a capacity exceeding 5.33 cubic feet (40 gallons) (0.15 m) are used for temporary storage of combustible debris, rubbish, and waste material, they shall have tight-fitting or self-closing lids. Such rubbish containers shall be constructed entirely of materials that comply with either of the following:

1. Noncombustible materials.
2. Materials that meet a peak rate of heat release not exceeding 300 kW/m when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m in the horizontal orientation.

3304.2 Spontaneous ignition. Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3304, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3304, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-3304, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-3305 Ignition source controls.

3305.1 Listed. Temporary heating devices shall be *listed* and labeled. The installation, maintenance and use of temporary heating devices shall be in accordance with the listing and the manufacturer's instructions.

3305.1.1 Oil-fired heaters. Oil-fired heaters shall comply with Section 605.

3305.1.2 LP-gas heaters. Fuel supplies for *liquefied-petroleum gas-fired* heaters shall comply with Chapter 61 and the *International Fuel Gas Code*.

3305.1.3 Refueling. Refueling operations for liquid-fueled equipment or appliances shall be conducted in accordance with Section 5705. The equipment or appliance shall be allowed to cool prior to refueling.

3305.1.4 Installation. Clearance to combustibles from temporary heating devices shall be maintained in accordance with the labeled equipment. When in operation, temporary heating devices shall be fixed in place and protected from damage, dislodgement or overturning in accordance with the manufacturer's instructions.

3305.1.5 Supervision. The use of temporary heating devices shall be supervised and maintained only by competent personnel.

3305.2 Smoking. Smoking shall be prohibited except in approved areas. Signs shall be posted in accordance with Section 310. In approved areas where smoking is permitted, approved ashtrays shall be provided in accordance with Section 310.

3305.5 Cutting and welding. Welding, cutting, open torches and other hot work operations and equipment shall comply with Chapter 35.

3305.6 Electrical. Temporary wiring for electrical power and lighting installations used in connection with the construction, *alteration* or *demolition of buildings*, structures, equipment or similar activities shall comply with NFPA 70.

3305.7 Cooking. Cooking shall be prohibited except in approved designated cooking areas separated from combustible materials by a minimum of 10 feet (3048 mm). Signs with a minimum letter height of 3 inches (76 mm) and a minimum brush stroke of 1/2 inch (13 mm) shall be posted in conspicuous locations in designated cooking areas and state:

DESIGNATED COOKING AREA
COOKING OUTSIDE OF A DESIGNATED
COOKING AREA IS PROHIBITED

3305.8 Portable generators. Portable generators used at construction and demolition sites shall comply with Section 1204.

3305.9 Hot work operations. The site safety director shall ensure hot work operations and permit procedures are in accordance with Chapter 35.

3305.10 Safeguarding roof operations general. Roofing operations utilizing heat-producing systems or other ignition sources shall be conducted in accordance with Sections 3305.10.1 and 3305.10.2 and Chapter 35.

3305.10.1 Asphalt and tar kettles. Asphalt and tar kettles shall be operated in accordance with Section 303.

3305.10.2 Fire extinguishers for roofing operations. Fire extinguishers shall comply with Section 906. There shall be not less than one multiple-purpose portable fire extinguisher with a minimum 3-A 40-B:C rating on the roof being covered or repaired.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3305, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3305, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3306 Fire protection systems and devices.

3306.1 Fire protection devices. The site safety director shall ensure that all fire protection equipment is maintained and serviced in accordance with this code. Fire protection equipment shall be inspected in accordance with the fire protection program.

3306.2 Impairment of fire protection systems. The site safety director shall ensure impairments to any fire protection system are in accordance with Section 901.

3306.3 Smoke detectors and smoke alarms. Smoke detectors and smoke alarms located in an area where airborne construction dust is expected shall be covered to prevent exposure to dust or shall be temporarily removed. Smoke detectors and alarms that were removed shall be replaced upon conclusion of dust-producing work. Smoke detectors and smoke alarms that were covered shall be inspected and cleaned, as necessary, upon conclusion of dust-producing work.

3306.4 Temporary covering of fire protection devices. Coverings placed on or over fire protection devices to protect them from damage during construction processes shall be immediately removed upon the completion of the construction processes in the room or area in which the devices are installed.

3306.5 Automatic sprinkler system. In buildings where an automatic sprinkler system is required by this code or the International Building Code, it shall be unlawful to occupy any portion of a building or structure until the automatic sprinkler system installation has been tested and approved, except as provided in Section 105.3.4.

3306.5.1 Operation of valves. Operation of sprinkler control valves shall be allowed only by properly authorized personnel and shall be accompanied by notification of duly designated parties. Where the sprinkler protection is being regularly turned off and on to facilitate connection of newly completed segments, the sprinkler control valves shall be checked at the end of each work period to ascertain that protection is in service.

3306.6 Portable fire extinguishers. Structures under construction, alteration or demolition shall be provided with not less than one approved portable fire extinguisher in accordance with Section 906 and sized for not less than ordinary hazard as follows:

1. At each stairway on all floor levels where combustible materials have accumulated.

2. In every storage and construction shed.

3. Additional portable fire extinguishers shall be provided where special hazards exist including, but not limited to, the storage and use of flammable and combustible liquids.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3306, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3307 Fire department site access and water supply.

3307.1 Required access. *Approved* vehicle access for fire fighting shall be provided to all construction or demolition sites. Vehicle access shall be provided to within 100 feet (30,480 mm) of temporary or permanent fire department connections. Vehicle access shall be provided by either temporary or permanent roads, capable of supporting vehicle loading under all weather conditions. Vehicle access shall be maintained until permanent fire apparatus access roads are available.

3307.1.1 Key boxes. Key boxes shall be provided as required by Chapter 5.

3307.1.2 Stairways required. Where *building* construction exceeds 40 feet (12,192 mm) in height above the lowest level of fire department vehicle access, a temporary or permanent stairway shall be provided. As construction progresses, such stairway shall be extended to within one floor of the highest point of construction having secured decking or flooring.

3307.1.3 Maintenance. Required *means of egress* and required *accessible means of egress* shall be maintained during construction and demolition, remodeling or *alterations* and additions to any building.

EXEMPTION: Approved temporary means of egress and accessible means of egress systems and facilities.

3307.2 Water supply for fire protection. An *approved* water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible building materials arrive on the site, on commencement of vertical combustible construction and on installation of a standpipe system in buildings under construction, in accordance with Sections 3307.2.1 through 3307.4.

EXCEPTION: The fire code official is authorized to reduce the fire-flow requirements for isolated buildings or a group of buildings in rural areas or small communities where the development of full fire-flow requirements is impractical.

3307.2.1 Combustible building materials. When combustible building materials of the building under construction are delivered to a site, a minimum fire flow of 500 gallons per minute (1893 L/m) shall be provided. The fire hydrant used to provide this fire-flow supply shall be within 500 feet (152 m) of the combustible building materials, as measured along an approved fire apparatus access lane. Where the site configuration is such that one fire hydrant cannot be located within 500 feet (152 m) of all combustible building materials, additional

fire hydrants shall be required to provide coverage in accordance with this section.

3307.2.2 Vertical construction of Types III, IV, and V construction. Prior to commencement of vertical construction of Type III, IV, or V buildings that utilize any combustible building materials, the fire flow required by Sections 3307.2.2.1 through 3307.2.2.3 shall be provided, accompanied by fire hydrants in sufficient quantity to deliver the required fire flow and proper coverage.

3307.2.2.1 Fire separation up to 30 feet. Where a *building* of Type III, IV, or V construction has a *fire separation distance* of less than 30 feet (9144 mm) from property lot lines, and an adjacent property has an existing structure or otherwise can be built on, the water supply shall provide either a minimum of 500 gallons per minute (1893 L/m) or the entire fire flow required for the building when constructed, whichever is greater.

3307.2.2.2 Fire separation of 30 feet up to 60 feet. Where a *building* of Type III, IV, or V construction has a *fire separation distance* of 30 feet (9144 mm) up to 60 feet (18,288 mm) from property lot lines, and an adjacent property has an existing structure or otherwise can be built on, the water supply shall provide a minimum of 500 gallons per minute (1893 L/m) or 50 percent of the fire flow required for the building when constructed, whichever is greater.

3307.2.2.3 Fire separation of 60 feet or greater. Where a building of Type III, IV, or V construction has a fire separation of 60 feet (18,288 mm) or greater from a property lot line, a water supply of 500 gallons per minute (1893 L/m) shall be provided.

3307.3 Vertical construction, Type I and II construction. If combustible building materials are delivered to the construction site, water supply in accordance with Section 3307.2.1 shall be provided. Additional water supply for fire flow is not required prior to commencing vertical construction of Type I and II buildings.

3307.4 Standpipe supply. Regardless of the presence of combustible building materials, the construction type or the *fire separation distance*, where a standpipe is required in accordance with Section 3307, a water supply providing a minimum flow of 500 gallons per minute (1893 L/m) shall be provided. The fire hydrant used for this water supply shall be located within 100 feet (30,480 mm) of the fire department connection supplying the standpipe.

3307.5 Standpipes. In *buildings* required to have standpipes by Section 905.3.1, not less than one standpipe shall be provided for use during construction. Such standpipes shall be installed prior to construction exceeding 40 feet (12,192 mm) in height above the lowest level of fire department vehicle access. Such standpipes shall be provided with fire department hose connections at locations adjacent to stairways complying with Section 3307.1.3. As construction progresses, such standpipes shall be extended to within one floor of the highest point of construction having secured decking or flooring.

3307.5.1 Buildings being demolished. Where a *building* is being demolished and a standpipe is existing within such a *building*, such standpipe shall be maintained in an operable condition so as to be available for use by the fire department. Such standpipe shall be demolished with the *building* but shall not be demolished more than one floor below the floor being demolished.

3307.5.2 Detailed requirements. Standpipes shall be installed in accordance with the provisions of Section 905.

EXCEPTION: Standpipes shall be either temporary or permanent in nature, and with or without a water supply, provided that such standpipes comply with the requirements of Section 905 as to capacity, outlets, and materials.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3307, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3307, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3308 Motorized construction equipment.

3308.1 Conditions of use. Internal-combustion-powered construction equipment shall be used in accordance with all of the following conditions:

1. Equipment shall be located so that exhausts do not discharge against combustible material.
2. Exhausts shall be piped to the outside of the building.
3. Equipment shall not be refueled while in operation.
4. Fuel for equipment shall be stored in an approved area outside of the building.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3308, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-3308, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-3308, filed 1/2/19, effective 7/1/19.]

WAC 51-54A-3309 Hazardous materials.

3309.1 Storage of flammable and combustible liquids. Storage of flammable and combustible liquids shall be in accordance with Section 5704.

3309.1.1 Class I and Class II liquids. The storage, use and handling of flammable and combustible liquids at construction sites shall be in accordance with Section 5706.2. Ventilation shall be provided for operations involving the application of materials containing flammable solvents.

3309.1.2 Housekeeping. Flammable and combustible liquid storage areas shall be maintained clear of combustible vegetation and waste materials. Such storage areas shall not be used for the storage of combustible materials.

3309.1.3 Precautions against fire. Sources of ignition and smoking shall be prohibited in flammable and combustible liquid storage areas. Signs shall be posted in accordance with Section 310.

3309.1.4 Handling at point of final use. Class I and II liquids shall be kept in approved safety containers.

3309.1.5 Leakage and spills. Leaking vessels shall be immediately repaired or taken out of service and spills shall be cleaned up and disposed of properly.

3309.2 Storage and handling of flammable gas. The storage, use, and handling of flammable gases shall comply with Chapter 58.

3309.2.1 Cleaning with flammable gas. Flammable gases shall not be used to clean or remove debris from piping open to the atmosphere.

3309.2.2 Pipe cleaning and purging. The cleaning and purging of flammable gas piping systems, including cleaning new or existing piping systems, purging piping systems into service and purging piping systems out of service, shall comply with NFPA 56.

EXCEPTIONS: 1. Compressed gas piping systems other than fuel gas piping systems where in accordance with Chapter 53.
 2. Piping systems regulated by the International Fuel Gas Code.
 3. Liquefied petroleum gas systems in accordance with Chapter 61.

3309.3 Storage and handling. Explosive materials shall be stored, used and handled in accordance with Chapter 56.

3309.3.1 Supervision. Blasting operations shall be conducted in accordance with Chapter 56.

3309.3.2 Demolition using explosives. Approved fire hoses for use by demolition personnel shall be maintained at the demolition site wherever explosives are used for demolition. Such fire hoses shall be connected to an approved water supply and shall be capable of being brought to bear on post-detonation fires anywhere on the site of the demolition operation.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3309, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3310 Additional safeguards for occupied buildings.

3310.1 Storage. Combustible materials associated with construction, demolition, remodeling or alterations to an occupied structure shall not be stored in exits, enclosures for stairways and ramps, or exit access corridors serving an occupant load of 30 or more.

EXCEPTIONS: 1. Where the only occupants are construction workers.
 2. Combustible materials that are temporarily accumulated to support work being performed when workers are present.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3310, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3311 Additional safeguards for Type I and II construction.

3311.1 Separations between construction areas. Separations used in Type I and Type II construction to separate construction areas from occupied portions of the building shall be constructed of materials that comply with one of the following:

1. Noncombustible materials.
2. Materials that exhibit a flame spread index not exceeding 25 when tested in accordance with ASTM E84 or UL 723.
3. Materials exhibiting a peak heat release rate not exceeding 300 kW/m when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m in the horizontal orientation on specimens at the thickness intended for use.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3311, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3312 Additional safeguards for Type IV-A, IV-B, and IV-C construction.

3312.1 Fire safety requirements for buildings of Types IV-A, IV-B, and IV-C construction. Buildings of Types IV-A, IV-B, and IV-C construction designed to be greater than six stories above grade plane shall comply with the following requirements during construction unless otherwise approved by the *fire code official*:

1. Standpipes shall be provided in accordance with Section 3307.
2. A water supply for fire department operations, as approved by the *fire code official* and the fire chief.
3. Where building construction exceeds six stories above grade plane and noncombustible protection is required by Section 602.4 of the *International Building Code*, at least one layer of noncombustible protection shall be installed on all building elements on floor levels, including mezzanines, more than four levels below active mass timber construction before additional floor levels can be erected.

EXCEPTIONS:

1. Shafts and vertical exit enclosures shall not be considered part of the active mass timber construction.
2. Noncombustible protection on the top surface of mass timber floor assemblies shall not be required before erecting additional floor levels.

4. Where building construction exceeds six stories above grade plane, required exterior wall coverings shall be installed on floor levels, including mezzanines, more than four levels below active mass timber construction before additional floor levels can be erected.

EXCEPTION: Shafts and vertical exit enclosures shall not be considered part of the active mass timber construction.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3312, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-3313 Water supply for fire protection. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3313, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-3314 Standpipes. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3314, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-3315 Automatic sprinkler system. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3315, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-3316 Portable fire extinguishers. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3316, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-3317 Motorized construction equipment. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3317, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-3318 Safeguarding roofing operations. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3318, filed 11/15/23, effective 3/16/24.]

WAC 51-54A-3601 Marinas—Scope.

3601.3 Permits. For permits to operate marine motor fuel-dispensing stations, application of flammable or combustible finishes, and hot works, see Section 105.5.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3601, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-3601, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-3601, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-3602 Definitions.

3602.1 Definitions. The following terms are defined in Chapter 2:

COVERED BOAT MOORAGE

FLOAT

GRAVITY-OPERATED DROP OUT VENTS

MARINA

PIER

VESSEL

WHARF

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-3602, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-3604 Fire protection equipment.

3604.2 Standpipes. Marinas and boatyards shall be equipped throughout with Class I manual, dry standpipe systems in accordance with NFPA 303. Systems shall be provided with hose connections located such that no point on the marina pier or float system exceeds 150 feet from a standpipe outlet.

3604.3 Access and water supply. Piers and wharves shall be provided with fire apparatus access roads and water-supply systems with on-site fire hydrants when required and *approved* by the *fire code official*. At least one fire hydrant capable of providing the required fire flow shall be provided within an *approved* distance of standpipe supply connections.

3604.4 Portable fire extinguishers. One 4A40BC rated fire extinguisher shall be provided at each standpipe hose connection. Additional portable fire extinguishers, suitable for the hazards involved, shall be provided and maintained in accordance with Section 906.

3604.7 Smoke and heat vents. Approved automatic smoke and heat vents shall be provided in covered boat moorage areas exceeding 2,500 sq. ft. (232 m²) in area, excluding roof overhangs.

EXCEPTION: Smoke and heat vents are not required in areas protected by automatic sprinklers.

3604.7.1 Design and installation. Where smoke and heat vents are required they shall be installed near the roof peak, evenly distributed and arranged so that at least one vent is over each covered berth. The effective vent area shall be calculated using a ratio of one square foot of vent to every fifteen square feet of covered berth area (1:15). Each vent shall provide a minimum opening size of 4 ft. x 4 ft.

3604.7.1.1 Smoke and heat vents. Smoke and heat vents shall operate automatically by actuation of a heat-responsive device rated at 100°F (56°C) above ambient.

EXCEPTION: Gravity-operated drop out vents.

3604.7.1.2 Gravity-operated drop out vents. Gravity-operated drop out vents shall fully open within 5 minutes after the vent cavity is exposed to a simulated fire represented by a time-temperature gradient that reaches an air temperature of 500°F (260°C) within 5 minutes.

3604.8 Draft curtains. Draft curtains shall be provided in covered boat moorage areas exceeding 2,500 sq. ft. (232 m²) in area, excluding roof overhangs.

EXCEPTION: Draft curtains are not required in areas protected by automatic sprinklers.

3604.8.1 Draft curtain construction. Draft curtains shall be constructed of sheet metal, gypsum board or other approved materials that provide equivalent performance to resist the passage of smoke. Joints and connections shall be smoke tight.

3604.8.2 Draft curtain location and depth. The maximum area protected by draft curtains shall not exceed 2,000 sq. ft. (186 m²) or two slips or berths, whichever is smaller. Draft curtains shall not extend past the piling line. Draft curtains shall have a minimum depth of 4 feet and shall not extend closer than 8 feet (2438 mm) to the walking surface of the pier.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3604, filed 6/14/22, 6/7/23, and

9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-3604, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-3800 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-3800, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-3800, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW. WSR 17-03-104, § 51-54A-3800, filed 1/17/17, effective 5/1/17.]

WAC 51-54A-3900 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3900, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-3900, filed 1/20/21, effective 2/20/21. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-3900, filed 1/2/19, effective 7/1/19.]

WAC 51-54A-3904 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3904, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-3904, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-3904, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-4000 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-4000, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-4000, filed 1/20/21, effective 2/20/21.]

WAC 51-54A-4900 Fixed guideway transit and passenger rail systems.

4901 Scope NFPA 130.

4901.1 General. Fixed guideway transit and passenger rail systems shall be in accordance with NFPA 130, as modified below.

4901.2 NFPA 130 Section 3.3.44.2. Add new definition as follows:

3.3.44.2 Traction power sub station (TPSS): A TPSS is an electrical substation consisting of switchgear transformers/rectifiers, emergency trip equipment, and other systems that converts AC electric power provided by the electrical power industry for public utility service to DC voltage to supply light rail vehicles with traction current.

4901.3 NFPA 130 Section 5.4.4 Modify NFPA 130 Sections 5.4.4.1 and 5.4.4.1.1 to read as follows:

5.4.4.1 An automatic sprinkler system shall be provided throughout enclosed stations.

- EXCEPTIONS:
1. Traction power substation (TPSS) when located in a transformer vault designed in accordance with the NFPA 70.
 2. Other high voltage equipment located in a transformer vault designed in accordance with the NFPA 70 when approved by the fire code official.
 3. Fire command centers, communication room(s), and signal rooms when protected with clean agent fire suppression and separated from other spaces with 2-hour fire rated construction.
 4. Other operational critical rooms when protected with clean agent fire suppression and separated from other spaces with 2-hour fire rated construction, when approved by the fire code official.

5.4.4.1.1 An automatic sprinkler system shall be provided in areas of open stations used for concessions, markets, storage areas and similar areas with combustibile loadings, and in trash rooms, electrical rooms, mechanical rooms, machinery rooms, communication rooms, and other enclosed rooms.

- EXCEPTIONS:
1. Stations at grade with less than 1,500 sq. ft. of ancillary area/ancillary space.
 2. Fire command centers, communication room(s), and signal rooms when protected with clean agent fire suppression and separated from other spaces with 2-hour fire rated construction.
 3. Other operational critical rooms when protected with clean agent fire suppression and separated from other spaces with 2-hour fire rated construction, when approved by the fire code official.

5.4.4.2 Sprinkler protection shall be permitted to be omitted in areas of open stations separated from the station by a distance of 20 feet.

4901.4 NFPA 130 Section 5.4.5. Modify NFPA 130 Sections 5.4.5.1 as follows:

5.4.5.1 Class I standpipes shall be installed in enclosed stations in accordance with International Fire Code Section 905 except as modified herein.

4901.5 NFPA 130 Section 5.4.6. Modify NFPA 130 Sections 5.4.6 as follows:

5.4.6 Portable fire extinguishers in such number, size, type, and location in accordance with the International Fire Code Section 906.

5.4.6.1 Portable fire extinguishers are not required in public areas of at-grade stations.

4901.6 NFPA 130 Section 5.2.2. Modify NFPA 130 Section 5.2.2.2 as follows:

5.2.2.2 Construction types shall conform to the requirements in the International Building Code, Chapter 6, unless otherwise exempted in this section.

Table 5.2.2.1

Minimum Construction Requirements for New Station Structures

Station Configuration	Construction Type†
Stations erected entirely above grade and in a separate building:	
Open stations	Type IIB
Enclosed stations	Type IIA
Stations erected entirely or partially below grade:	
Open above grade portions of below grade structures*	Type IIA
Below grade portions of structures	Type IB

Station Configuration	Construction Type†
Below grade structures with occupant loads exceeding 1000	Type IA

* Roofs not supporting an occupancy above are not required to have a fire resistance rating.

† Construction types are in accordance with the International Building Code.

4901.7 NFPA 130 Section 5.2.2. Modify NFPA 130 Section 5.2.4.3 as follows:

5.2.4.3 Ancillary spaces. Fire resistance ratings of separations between ancillary occupancies shall be established as required for accessory occupancies and incidental uses by the International Building Code and in accordance with ASTM E119 and ANSI/UL 263.

4901.8 NFPA 130 Section 5.2.5. Modify NFPA 130 Section 5.2.5.4 as follows:

5.2.5.4 Materials used as interior finish in open stations shall comply with the requirements of the International Building Code, Chapter 8.

4901.9 NFPA 130 Section 5.3.1. Modify NFPA 130 Section 5.3.1.1 as follows:

5.3.1.1 The provisions for means of egress for a station shall comply with the International Building Code, Chapter 10, except as herein modified.

4901.10 NFPA 130 Section 5.3.2. Add a New Section to NFPA 130 Section 5.3.2.2.1 as follows:

5.3.2.2.1 Where station occupancy is anticipated to be greater than design capacity during a major event the operating agency shall initiate approved measures to restrict access to the station, when required by the fire code official, to ensure existing means of egress are adequate as an alternative to account for peak ridership associated with major events.

4901.11 NFPA 130 Section 5.3.4. Modify NFPA 130 Section 5.3.2.4(1) as follows:

(1) The occupant load for that area shall be determined in accordance with the provisions of the International Building Code as appropriate for the use.

4901.12 NFPA 130 Section 5.3.3. Modify NFPA 130 Section 5.3.3.4 as follows:

5.3.3.4 Travel distance. For open stations the maximum travel distance on the platform to a point at which a means of egress route leaves the platform shall not exceed 100 m (325 ft.). For enclosed stations the travel distance to an exit shall not exceed 76 m (250 ft.).

4901.13 NFPA 130 Section 5.3.5. Modify NFPA 130 Section 5.3.5.3(2) as follows:

(2)* Travel speed - 14.6 m/min (48 ft./min) (indicates vertical component of travel speed).

5.3.2.4 Where an area within a station is intended for use by other than passengers or employees, the following parameters shall apply:

1. The occupant load for that area shall be determined in accordance with the provisions of the IBC NFPA 101 as appropriate for the use.

2. The additional occupant load shall be included in determining the required egress from that area.

3. The additional occupant load shall be permitted to be omitted from the station occupant load where the area has independent means of egress of sufficient number and capacity.

5.3.3.4 Travel distance. For open stations the maximum travel distance on the platform to a point at which a means of egress route leaves the platform shall not exceed 100 m (325 ft.). For enclosed stations the travel distance to an exit shall not exceed 76 m (250 ft.).

5.3.5.4 Escalators shall not account for more than one-half of the egress capacity at any one level.

4901.14 NFPA 130 Section 5.3.5. Delete NFPA 130 Section 5.3.5.5.

4901.15 NFPA 130 Section 5.3.7. Modify NFPA 130 Section 5.3.7 as follows:

5.3.7* Doors, gates, security grilles and exit hatches.

5.3.7.1 The egress capacity for doors and gates in a means of egress serving public areas shall be computed as follows:

1. Sixty people per minute (p/min) for single leaf doors and gates.

2.* 0.0819 p/mm-min (2.08 p/in.-min) for biparting multileaf doors and gates measured for the clear width dimension.

5.3.7.2.1 Security grilles are allowed when designed and operated in accordance with the International Building Code.

4901.16 NFPA 130 Section 5.3.9. Modify NFPA 130 Section 5.3.9 as follows:

5.3.9* Horizontal exits. Horizontal exits shall comply with the International Building Code Section 1026.

4901.17 NFPA 130 Section 5.3.11. Modify NFPA 130 Section 5.3.11 as follows:

5.3.11.1 Illumination of the means of egress in stations, including escalators that are considered a means of egress, shall be in accordance with the International Building Code Section 1008.

5.3.11.2 Means of egress, including escalators considered as means of egress, shall be provided with a system of emergency lighting in accordance with the International Building Code Section 1008.

4901.18 NFPA 130 Section 5.4.7. Modify NFPA 130 Section 5.4.7 as follows:

5.4.7 Emergency ventilation shall be provided in enclosed stations in accordance with Chapter 7 and the International Building Code Section 909.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-4900, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-4900, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

WAC 51-54A-5003 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-5003, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-5003, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-5306 Medical gas systems.

5306.1 General. Compressed gases at hospitals and similar facilities intended for inhalation or sedation including, but not limited to, analgesia systems for dentistry, podiatry, veterinary and similar uses shall comply with Sections 5306.2 through 5306.5 in addition to other requirements of this chapter.

EXCEPTION: All new distribution piping, supply manifolds, connections, regulators, valves, alarms, sensors and associated equipment shall be in accordance with the Plumbing Code.

5306.5 Medical gas systems. The maintenance and testing of medical gas systems including, but not limited to, distribution piping, supply manifolds, connections, pressure regulators and relief devices and valves, shall comply with the maintenance and testing requirements of NFPA 99 and the general provisions of this chapter.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-5306, filed 11/15/23, effective 3/16/24; WSR 20-01-162, § 51-54A-5306, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5306, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5307 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5307, filed 12/18/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-5307, filed 4/25/17, effective 5/26/17.]

WAC 51-54A-5601 General.

5601.1 Scope. The provisions of this chapter shall govern the possession, manufacture, storage, handling, sale and use of explosives, explosive materials, and small arms ammunition. The manufacture, storage, handling, sale and use of fireworks shall be governed by chapter 70.77 RCW, and by chapter 212-17 WAC and local ordinances consistent with chapter 212-17 WAC.

EXCEPTIONS:

1. The Armed Forces of the United States, Coast Guard or National Guard.
2. Explosives in forms prescribed by the official United States Pharmacopoeia.
3. The possession, storage and use of small arms ammunition when packaged in accordance with DOT packaging requirements.
4. The possession, storage and use of not more than 1 pound (0.454 kg) of commercially manufactured sporting black powder, 20 pounds (9 kg) of smokeless powder and 10,000 small arms primers for hand loading of small arms ammunition for personal consumption.
5. The use of explosive materials by federal, state and local regulatory, law enforcement and fire agencies acting in their official capacities.
6. Special industrial explosive devices which in the aggregate contain less than 50 pounds (23 kg) of explosive materials.
7. The possession, storage and use of blank industrial-power load cartridges when packaged in accordance with DOT packaging regulations.
8. Transportation in accordance with DOT 49 C.F.R. Parts 100-185.
9. Items preempted by federal regulations.

5601.1.1 Explosive material standard. In addition to the requirements of this chapter, NFPA 495 shall govern the manufacture, transporta-

tion, storage, sale, handling and use of explosive materials. See also chapter 70.74 RCW and chapter 296-52 WAC.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5601, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5601, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5704 Storage.

5704.2.11 Underground tanks. Underground storage of flammable and combustible liquids in tanks shall comply with Section 5704.2 and Sections 5704.2.11.1 through 5704.2.11.4.2. Corrosion protection shall comply with WAC 173-360-305.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5704, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5704, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5706 Special operations.

5706.5.4.5 Commercial, industrial, governmental or manufacturing. Dispensing of Class II and III motor vehicle fuel from tank vehicles into the fuel tanks of motor vehicles located at commercial, industrial, governmental or manufacturing establishments is allowed where permitted, provided such dispensing operations are conducted in accordance with the following: (Those sections not noted here remain unchanged.)

12. Fuel delivery vehicles shall be equipped with spill clean-up supplies in accordance with the department of ecology's Source Control Best Management Practices. Such supplies shall be readily available for deployment by the operator at all times and include nonwater absorbents capable of absorbing 15 gallons (56.76 L) of diesel fuel, storm drain plug or cover kit, a nonwater absorbent containment boom of a minimum 10 foot long (3038 mm) length with a 12-gallon (45.41 L) absorbent capacity, a nonmetallic shovel, and two 5-gallon (19 L) buckets with lids.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5706, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5707 Section 5707—On-demand mobile fueling operations.

5707.1 General. On-demand mobile fueling operations that dispense Class I, II and III liquids into the fuel tanks of motor vehicles shall comply with Sections 5707.1 through 5707.6.6.

EXCEPTION: Fueling from an *approved* portable container in cases of an emergency or for personal use.

5707.1.1 Approval required. Mobile fueling operations shall not be conducted without first obtaining a *permit* and approval from the fire code official. Mobile fueling operations shall occur only at *approved* locations. The fire code official is authorized to *approve* individual locations or geographic areas where mobile fueling is allowed.

5707.1.2 Coordination of permits. *Permits* across multiple authorities having jurisdiction shall be coordinated in accordance with Sections 5707.1.2.1 through 5707.1.2.4.

5707.1.2.1 Acceptance of permits issued by other authorities having jurisdiction. Local authorities having jurisdiction that allow mobile on demand fueling trucks may accept conforming *permits* issued and/or inspections performed by any other local authorities having jurisdiction in Washington state. Local authorities having jurisdiction that choose to accept conforming *permits* issued by other local authorities having jurisdiction in Washington state retain the right to enforce the provisions of this section.

5707.1.2.2 Local authorities having jurisdiction not offering operator or truck certification. A conforming operator or vehicle *permit* issued by one local authority having jurisdiction shall be recognized and accepted by all local authorities having jurisdiction in Washington state, if those local authority having jurisdictions allow mobile on-demand fueling and do not offer such operator or truck certification. Under no circumstances will an issuing local authority having jurisdiction be expected to perform permissive inspections beyond their jurisdiction.

5707.1.2.3 Commencing permit issuance. When a local authority having jurisdiction that has previously authorized mobile fueling operations but not issued their own *permits* commences *permit* issuance for mobile fueling operations or vehicles, that local authority having jurisdiction shall continue to accept *permits* previously issued by another local authority having jurisdiction in Washington state for three months or until their expiration date, whichever is sooner.

5707.1.2.4 Permit record maintenance. Issuing local authorities having jurisdiction shall maintain a publicly available list of current *permits* or other information source to enable all parties to have information about whether *permits* are in good standing.

5707.2 Mobile fueling vehicle. An on-demand mobile fueling vehicle shall be utilized in on-demand fueling operations for the dispensing of Class I, II or III liquids into the fuel tanks of motor vehicles and shall comply with Sections 5707.2.1 and 5707.2.2.

5707.2.1 Mobile fueling vehicle classifications. An on-demand mobile fueling vehicle shall be classified as one of the following:

1. **Type 1 Mobile Fueling Vehicle** - A tank vehicle that complies with NFPA 385 and that has chassis-mounted tanks where the aggregate capacity does not exceed 1600 gallons (6057 L).

2. **Type 2 Mobile Fueling Vehicle** - A vehicle with one or more chassis-mounted tanks or chassis-mounted containers, not to exceed 110 gallons (415 L) capacity for each tank or container and having an aggregate capacity not exceeding 800 gallons (3028 L) or the weight capacity of the vehicle in accordance with DOTn.

3. **Type 3 Mobile Fueling Vehicle** - A vehicle that carries a maximum aggregate capacity of 60 gallons (227 L) of motor fuel in metal safety cans listed in accordance with UL 30 or other approved metal containers, each not to exceed 5 gallons (19 L) in capacity.

5707.2.2 Mobile fueling vehicle requirements. Each mobile fueling vehicle shall comply with all local, state and federal requirements, and the following:

1. Mobile fueling vehicles with a chassis-mounted tank in excess of 110 gallons (415 L) shall also comply with the requirements of Section 5706.6 and NFPA 385.

2. The mobile fueling vehicle and its equipment shall be maintained in good repair.

3. Safety cans and *approved* metal containers shall be secured to the mobile fueling vehicle except when in use.

4. Fueling a motor vehicle from tanks or containers mounted in a trailer connected to a mobile fueling vehicle shall be prohibited.

5707.3 Required documents. Documents developed to comply with Sections 5707.3.1 through 5707.3.3 shall be updated as necessary by the owner of the mobile fueling operation and shall be maintained in compliance with Section 108.3.

5707.3.1 Safety and emergency response plan. Mobile fueling operators shall have an *approved* written safety and emergency response plan that establishes policies and procedures for fire safety, spill prevention and control, personnel training and compliance with other applicable requirements of this code. The safety and emergency response plan shall specifically address and require that all operators assess surroundings prior to fueling to consider the presence of items listed in Section 5707.3.3.

5707.3.2 Training records. Mobile fueling vehicles shall be operated only by designated personnel who are trained on proper fueling procedures and the safety and emergency response plan. Training records of operators shall be maintained.

5707.3.3 Site plan. Where required by the fire code official, a site plan shall be developed for each location or area at which mobile fueling occurs. The site plan shall be in sufficient detail to indicate but not be limited to the following:

1. All buildings, structures.
2. Lot lines or property lines.
3. Electric car chargers.
4. Solar photovoltaic parking lot canopies.
5. Appurtenances on-site and their use or function.
6. All uses adjacent to the lot lines of the site.
7. Fueling locations.
8. Locations of all storm drain openings and adjacent waterways or wetlands.
9. Information regarding slope, natural drainage, curbing, and impounding.
10. How a spill will be kept on the site property.
11. Scale of the site plan.

5707.3.4 Tiered sites. Where a site permitting process is required by the local jurisdiction, a site shall be designated by the fire code official to be one of the following and based on local provisions as necessitated by zoning laws, environmental laws, public safety, and other characteristics.

5707.3.4.1 Tier 1 sites. Sites that do not present atypical geographic, safety or environmental concerns shall be provided expedited permitting review and shall allow *permit* issuance prior to site inspection. The fire code official may impose additional conditions and may perform a site inspection during the period of *permit* validity.

5707.3.4.2 Tier 2 sites. Sites that require an inspection shall be approved by the fire code official prior to *permit* issuance.

5707.4 Mobile fueling areas. During fueling, the mobile fueling vehicle and point of connection of the vehicle being fueled shall not be located on public streets, public ways or inside buildings. Fueling on the roof level of parking structures or other buildings is prohibited.

5707.4.1 Separation. During fueling, the point of connection of the vehicle being fueled shall not take place within 25 feet (7620 mm) of buildings, lot lines, property lines or combustible storage. Mobile fueling vehicles shall not park within 10 feet (3048 mm) of buildings, lot lines, property lines or combustible storage.

EXCEPTIONS: 1. The fire code official shall be authorized to decrease the separation distance for dispensing from metal safety cans or other *approved* metal containers in accordance with Section 5707.2.
 2. The point of fueling shall not take place within 10 feet (3048 mm) of buildings, lot lines, property lines or combustible storage when the mobile fueling vehicle has an approved vapor recovery system or is servicing vehicles with on board refueling vapor recovery.

Where dispensing operations occur within 15 feet (4572 mm) of a storm drain, an *approved* storm drain cover or an *approved* equivalent method that will prevent any fuel from reaching the drain shall be used.

5707.4.2 Sources of ignition. Smoking, open flames and other sources of ignition shall be prohibited within 25 feet (7620 mm) of fuel dispensing activities. Signs prohibiting smoking or open flames within 25 feet (7620 mm) of the vehicle or the point of fueling shall be prominently posted on the mobile fueling vehicle. The engines of vehicles being fueled shall be shut off during fueling.

5707.4.3 Electrical equipment. Mobile fueling shall not occur within 20 feet of electrical equipment located within 18 inches of the ground unless such electrical equipment is rated for Class 1, Division 2 hazardous locations in accordance with NFPA 70.

5707.5 Equipment. Mobile fueling equipment shall comply with Sections 5707.5.1 through 5707.5.5.

5707.5.1 Dispensing hoses and nozzles. Where equipped, the dispensing hose shall not exceed 50 feet (15240 mm) in length. The dispensing nozzles and hoses shall be of an *approved* and *listed* type. Where metal-to-metal contact cannot be made between the nozzle and the fuel fill opening, then a means for bonding the mobile fueling vehicle to the motor vehicle shall be provided and employed during fueling operations.

5707.5.2 Break-away device. A listed break-away device shall be provided at the nozzle.

EXCEPTION: Mobile fueling vehicles equipped with an approved brake interlock tied to the nozzle holder that prohibits movement of the mobile fueling vehicle when the nozzle is removed from its holder or tied to the delivery of fuel that prevents activation of the pumping system.

5707.5.3 Shut-off valve and fuel limit. Mobile fueling vehicles shall be equipped with a *listed* shut-off valve assembly and a fuel limit switch set to a maximum of 30 gallons (116 L).

5707.5.4 Fire extinguisher. An *approved* portable fire extinguisher complying with Section 906 with a minimum rating of 4A:80-B:C shall be provided on the mobile fueling vehicle with signage clearly indicating its location.

5707.5.5 Spill kit. Mobile fueling vehicles shall contain a minimum 5 gallon (19 L) spill kit of an *approved* type.

5707.6 Operations. Mobile fueling vehicles shall be constantly attended during fueling operations with brakes set and warning lights in operation. Mobile fueling vehicles shall not obstruct emergency vehicle access roads.

5707.6.1 Dispensing hose. Where equipped, mobile fueling vehicles shall be positioned in a manner to preclude traffic from driving over the dispensing hose. The dispensing hose shall be properly placed on an *approved* reel or in an *approved* compartment prior to moving the mobile fueling vehicle.

5707.6.2 Drip control. Operators shall place a drip pan or an absorbent pillow under the nozzle and each fuel fill opening prior to and during dispensing operations to catch drips.

5707.6.3 Safety cones. Safety cones or other visual barriers shall be employed as warning devices to highlight the vehicle fueling area. Signs prohibiting smoking or open flames within 25 feet (7620 mm) shall be prominently posted in the vehicle fueling area.

5707.6.4 Vehicle lights. The mobile fueling vehicle flasher lights shall be in operation while dispensing operations are in progress.

5707.6.5 Nighttime deliveries. Nighttime deliveries shall only be made in areas adequately lighted per WAC 296-800-21005.

5707.6.6 Spill reporting. Spills shall be reported in accordance with Section 5003.3.1.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-5707, filed 11/15/23, effective 3/16/24. Statutory Authority: RCW 19.27.077, 19.27.031 and 19.27.074. WSR 21-13-023, § 51-54A-5707, filed 6/9/21, effective 7/10/21.]

WAC 51-54A-6108 Fire protection.

6108.1 General. Storage, handling and transportation of liquefied petroleum gas (LP-gas) and the installation of LP-gas equipment pertinent to systems for such uses shall comply with this chapter and NFPA 58. Properties of LP-gas shall be determined in accordance with Appendix B of NFPA 58.

EXCEPTION: The use and storage of listed propane fired barbeque grills on R-2 decks and balconies with an approved container not exceeding a water capacity of 20 pounds (9 kg) that maintain a minimum clearance of 18 inches on all sides, unless listed for lesser clearances.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-6108, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-6108, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-8000 Referenced standards.

NFPA 13-19: Standard for the Installation of Sprinkler Systems (except 9.3.6.3(5)) 903.3.1.1, 903.3.2, 903.3.8.2, 903.3.8.5, 904.13, 905.3.4, 907.6.4, 914.3.2, 1019.3, 1103.4.8, 3201.1, 3204.2, 3205.5, Table 3206.2, 3206.4.1, 3206.10, 3207.2, 3207.2.1, 3208.2.2, 3208.2.2.1, 3208.4, 3210.1, 3401.1, 5104.1, 5104.1.1, 5106.5.7, 5704.3.3.9, Table 5704.3.6.3(7), 5704.3.7.5.1, 5704.3.8.4

NFPA 33-18 Membrane Enclosures 2404.3.5

NFPA 96-21 Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations 606.2, 606.3, 904.13

NFPA 130-20 Standard for Fixed Guideway Transit and Passenger Rail Systems 4901.1

NFPA 855-23 Standard for the Installation of Stationary Energy Storage Systems 1201.1

UL 142A-2018: Special Purpose Above ground Tanks for Specific Flammable or Combustible Liquids 605.4

UL 2272-2016: Electrical Systems for Personal E-Mobility Devices 323.2

UL 2849-2020: Electrical Systems for eBikes 323.2

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-22-119, § 51-54A-8000, filed 10/31/23, effective 3/15/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-8000, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-8000, filed 1/2/19, effective 7/1/19. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-8000, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-8000, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-8100 Reserved.

[Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-8100, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-8100, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-8200 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-8200, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-162, § 51-54A-8200, filed 12/18/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-8200, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-8200, filed 1/16/16, effective 7/1/16.]