

WAC 51-54A-3304 Protection of combustible materials.

3304.1 Combustible debris, rubbish, and waste. Combustible debris, rubbish, and waste material shall comply with the requirements of Sections 3304.1.1 through 3304.2.

3304.1.1 Combustible waste material accumulation. Combustible debris, rubbish, and waste material shall not be accumulated within *buildings*.

3304.1.2 Combustible waste material removal. Combustible debris, rubbish, and waste material shall be removed from *buildings* at the end of each shift of work.

3304.1.3 Rubbish containers. Where rubbish containers with a capacity exceeding 5.33 cubic feet (40 gallons) (0.15 m) are used for temporary storage of combustible debris, rubbish, and waste material, they shall have tight-fitting or self-closing lids. Such rubbish containers shall be constructed entirely of materials that comply with either of the following:

1. Noncombustible materials.
2. Materials that meet a peak rate of heat release not exceeding 300 kW/m when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m in the horizontal orientation.

3304.2 Spontaneous ignition. Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3304, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3304, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-3304, filed 11/27/19, effective 7/1/20.]