

**WAC 51-56-1300 Chapter 13—Health care facilities and medical gas and vacuum systems.**

**Part II Medical Gas and Vacuum Systems**

**1303.8 Water Mains for Hospitals.** Hospitals shall be provided with not less than two *approved potable water* mains that are installed in such a manner as to prevent the interruption of water service.

**1305.3 Minimum Station Outlets/Inlets.** Station outlets and inlets for medical gas and medical vacuum systems for facilities licensed or certified by Washington state department of health (DOH) or Washington state department of social and health services (DSHS) shall be provided as listed in chapters 246-320 and 246-330 WAC as required by the applicable licensing rules as applied by DOH construction review services. All other medical gas and medical vacuum systems shall be provided as listed in Table 1305.3.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-02-044, § 51-56-1300, filed 12/30/15, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-054, § 51-56-1300, filed 2/1/13, effective 7/1/13; WSR 10-03-101, § 51-56-1300, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.190, 19.27.020 and chapters 19.27 and 34.05 RCW. WSR 07-01-094, § 51-56-1300, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 04-01-110, § 51-56-1300, filed 12/17/03, effective 7/1/04; WSR 02-01-114, § 51-56-1300, filed 12/18/01, effective 7/1/02.]