

WAC 212-44-067 Exiting. (1) Not less than two exits shall be accessible from every part of each floor being used for birth services or uses incidental thereto, including floor levels below the street floor.

(2) Exits shall be remote from each other and shall be arranged to minimize the possibility that both may be blocked by any emergency.

[Statutory Authority: RCW 18.46.110. WSR 80-15-077 (Order FM 80-1), § 212-44-067, filed 10/20/80.]