

**WAC 212-44-069 Vertical openings.** Every stairway, elevator shaft, light and ventilation shaft, chute, and other opening between stories shall be enclosed or protected to prevent the spread of fire or smoke from one floor to another.

[Statutory Authority: RCW 18.46.110. WSR 80-15-077 (Order FM 80-1), § 212-44-069, filed 10/20/80.]