

WAC 212-44-072 Fire extinguishers. At least one approved fire extinguisher suitable for use on fires in ordinary combustibles shall be provided on each floor level. Additional fire extinguishers may also be required due to area, travel distance or special hazards.

[Statutory Authority: RCW 18.46.110. WSR 80-15-077 (Order FM 80-1), § 212-44-072, filed 10/20/80.]