

WAC 212-44-077 Protection from hazards. Any area used for general storage, and boiler or furnace rooms shall be separated from other parts of the building by construction having a fire-resistance rating conforming to the general construction requirements of the building type.

Central heating plants and other fuel-burning appliances shall be properly maintained and cleaned at frequent intervals. The surrounding area shall be kept free of rubbish and combustible storage.

[Statutory Authority: RCW 18.46.110. WSR 80-15-077 (Order FM 80-1), § 212-44-077, filed 10/20/80.]