

WAC 212-44-100 Equipment maintenance. Every required automatic sprinkler system, fire detection and alarm system, exit lighting, fire door and other item of equipment required by this regulation or the applicable building and/or fire code shall be continuously maintained in proper operating condition. Equipment shall be tested or operated in accordance with manufacturer's recommendation and/or at sufficient intervals to assure reliability. Records of all tests and inspections shall be maintained for review. Tests and inspections shall be under the supervision of a responsible person.

[Order FM-77-3, § 212-44-100, filed 12/8/77.]