

WAC 246-272C-0245 Additional requirements for trash tanks. (1)

Trash tanks must be designed and constructed for use as a pretreatment tank or compartment.

(2) Trash tank volume must not be used as part of the calculations of the required septic tank volume.

[Statutory Authority: RCW 43.20.050 (2) and (3). WSR 09-23-119, § 246-272C-0245, filed 11/18/09, effective 12/19/09.]