

WAC 246-291-140 Water system planning and disclosure requirements. (1) A purveyor submitting a new or expanding Group B system design for approval shall provide the following information to the department or health officer:

- (a) The system's management and ownership;
- (b) The system's service area and existing and proposed major facilities;
- (c) The maximum number of service connections the system can safely and reliably supply;
- (d) The relationship and compatibility with other locally adopted plans;
- (e) The amount of revenue needed to operate and maintain the system, and a plan to meet revenue needs;
- (f) A cross-connection control plan if any existing cross-connections are identified;
- (g) Security measures under the strict control of the purveyor to be provided to protect the water source, water storage reservoir, and the distribution system;
- (h) For systems that will use sources with a well pump test indicating a yield of 5.0 gpm or less, a contingency plan describing short-term and long-term measures to restore water to consumers in the event the well(s) cannot provide an adequate supply of water;
- (i) The public notification procedures that the purveyor will use as required under WAC 246-291-360.

(2) A purveyor shall record the following information on each customer's property title before providing water from the Group B system to any service connection:

- (a) System name and a department issued public water system identification number;
- (b) System owner name and contact information;
- (c) The following statement: "This property is served by a Group B public water system that has a design approval under chapter 246-291 Washington Administrative Code";
- (d) Parcel numbers to be served by the system;
- (e) Indicate if the system is designed and constructed to provide fire suppression;
- (f) A copy of any waiver granted under WAC 246-291-060 to the purveyor and any required monitoring and reporting;
- (g) Indicate:
 - (i) If service connections are metered or not;
 - (ii) If the purveyor intends to monitor the system for contaminants;
 - (iii) How often monitoring will occur; and
 - (iv) How the consumers of the system will be notified of monitoring results;
- (h) Contact information for the approving authority (department or local health jurisdiction);
- (i) The type of source treatment provided for any contaminants that exceed secondary MCLs;
- (j) Instructions about how to obtain a copy of the agreements for consumers, if one exists; and
- (k) Other information, as directed by the department or health officer.

[Statutory Authority: RCW 43.20.050 and chapter 70.119A RCW. WSR 12-24-070, § 246-291-140, filed 12/4/12, effective 1/1/14. Statutory Authority: RCW 43.20.050. WSR 95-20-078, § 246-291-140, filed 10/4/95,

effective 11/4/95; WSR 94-14-002, § 246-291-140, filed 6/22/94, effective 7/23/94.]