

WAC 246-360-140 Ventilation. (1) The licensee must provide ventilation in all lodging units, kitchen areas, bathrooms, water closet rooms, and laundry rooms.

(2) All areas of the building must be ventilated to minimize odors and moisture. The ventilation system must be in compliance with the Washington Ventilation and Indoor Air Quality Code, chapter 51-13 WAC.

[Statutory Authority: Chapter 70.62 RCW. WSR 04-24-002, § 246-360-140, filed 11/18/04, effective 4/1/05. Statutory Authority: RCW 70.62.240. WSR 94-23-077, § 246-360-140, filed 11/16/94, effective 12/17/94. Statutory Authority: RCW 43.20.050. WSR 91-02-051 (Order 124B), re-coded as § 246-360-140, filed 12/27/90, effective 1/31/91; WSR 89-11-058 (Order 328), § 248-144-151, filed 5/17/89.]