

**WAC 296-150C-1500 Safety devices—Water heater relief valves.**

In addition to requirements of the Washington State Ventilation and Indoor Air Quality Code:

(1) All water heaters must be installed with approved fully automatic valve or valves designed to provide temperature and pressure relief. Temperature and pressure relief valves must be tested and approved to ANSI Z21.22 standard or equal.

(2) Any temperature relief valve or combined pressure and temperature relief valve installed for this purpose must have the temperature sensing element immersed in the hottest water within the upper six inches of the tank. It must be set to start relieving at a pressure of 150 psi or the rated working pressure of the tank, whichever is lower, and at or below a water temperature of 210 degrees Fahrenheit.

(3) Relief valves must be provided with full-sized drains. Drains must be directed to the exterior sides of the unit, exiting at least six inches above the ground, and each drain pipe must exhaust with a ninety degree downward turn. Drain lines must be of a material approved for hot water distribution and must drain fully by gravity, must not be trapped, and must not have their outlets threaded.

[Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-1500, filed 10/23/96, effective 11/25/96.]