

**WAC 296-150V-0300 When is design-plan approval required?** Design plans for conversion vendor units and medical units are required for units that are sold, leased, or used in Washington state and must be approved when:

(1) Conversion vendor units that contain one or more of the following components:

(a) Concentrated loads exceeding five hundred pounds (see WAC 296-150V-0930);

(b) Fuel gas piping systems and equipment;

(c) Solid fuel burning equipment;

(d) Fire suppression systems;

(e) Commercial hoods;

(f) Electrical systems and equipment in excess of 30 amps/120 volts;

(g) Electrical systems with more than five circuits;

(h) Electrical systems incorporating photovoltaic energy, fuel cell energy, or other alternative energy systems;

(i) Plumbing drainage systems conveying solid or bodily waste.

(2) Medical units.

(3) Modification of an approved design plan through addendums;

(4) Addition of options to an approved design plan through addendums.

[Statutory Authority: Chapter 43.22 RCW. WSR 16-13-119, § 296-150V-0300, filed 6/21/16, effective 6/21/16; WSR 99-18-069, § 296-150V-0300, filed 8/31/99, effective 10/1/99.]